



KR0100830

KAERI/TR-1663/2000

기술 보고서

Fabrication of a CANFLEX-RU Designed Bundle
for Power Ramp Irradiation Test in NRU

November 2000

Korea Atomic Energy Research Institute

32 / 42

제 출 문

한국원자력연구소장 귀하

본 보고서를 중수로용 순환우라늄 핵연료 기술개발 과제의 “Fabrication of a CANFLEX-RU Designed Bundle for Power Ramp Irradiation Test in NRU” 기술보고서로 제출합니다.

2000년 11월

조문성 (중수로용 순환우라늄핵연료 기술개발과제)

Table of Contents

<u>Section</u>	<u>Page</u>
1. Introduction	4
2. Quality Assurance Plan	4
3. Materials	5
4. Special Processes	6
5. Fabrication	8
6. Nonconformance	13
7. Conclusion	13
8. References	14
Attachments	

1. Introduction

The BDL-443 CANFLEX-RU bundle AKW was fabricated at Korea Atomic Energy Research Institute (KAERI) for power ramp irradiation testing in NRU reactor. The bundle was fabricated with IDR and ADU fuel pellets in adjacent elements and contains fuel pellets enriched to 1.65 wt% ^{235}U in the outer and intermediate rings and also contains pellets enriched to 2.00 wt% ^{235}U in the inner ring. This bundle does not have a center element to allow for insertion on a hanger bar.

KAERI produced the IDR pellets with the IDR-source UO_2 powder supplied by BNFL. ADU pellets were fabricated and supplied by AECL. Bundle kits (Zircaloy-4 end plates, end plugs, and sheaths with brazed appendages) manufactured at KAERI earlier in 1996 were used for the fabrication of the bundle⁽¹⁾.

Brief history of the bundle fabrication is summarized as follows:

Apr. 1998	Receipt of IDR powder from BNFL
May-July 1998	Fabrication of IDR pellets
Jan. 1999	Receipt of ADU pellets from AECL
Jan.-Feb. 1999	Fabrication of the Bundle
Mar.-Aug. 1999	Application for USDOE approval for sending ADU pellets back to AECL
Sep. 1999	Shipping of the bundle to AECL
Sep. 1999	Issuance of the fabrication report KF-FR-99-01 Rev.0 ⁽²⁾

All fabrication works of the KAERI bundle were performed in collaboration with the CANFLEX project team of KEPCO Nuclear Fuel Company Ltd.

2. Quality Assurance Plan

Provisions in the following quality document were implemented as appropriately for the fabrication of the CANFLEX bundle.

- Quality Assurance Manual for HWR Fuel Project⁽³⁾

This document outlines the responsibilities and procedures for the quality assurance of the CANFLEX bundle. Verification of end-closure welding and qualification of bundle assembly welding was conducted before the start of fabrication. The fabrication activities were carried out using established and approved manufacturing operating procedures and inspection procedures.

3. Materials

3.1 IDR Fuel Pellets

3.1.1 Fabrication

Two IDR-derived powders (natural and 2.67% U-235) were supplied by British Nuclear Fuels plc (BNFL). Analysis results for the starting uranium dioxide powders are given in Appendix 1. The two powders were blended to produce 1.65% and 2.0% IDR-source UO₂ powders and were fabricated into the pellets of two different diameters.

3.1.2 Characterization

Pellets for inspection were chosen at random following centerless grinding. A summary of the characteristics measured, methods used and accuracy of the methods is given in Table 1. Analysis results are summarized in Table 2

Table 1 IDR Pellet Characterization Methods and their Associated Accuracy

Characteristic Measured	Method	Accuracy	Procedure
Chamfer Width	Stereo Microscope	0.02mm	QCI-163 ⁽⁴⁾
Diameter	Micrometer	0.001mm	"
Height	Digital Vernier Calipers	0.01mm	"
Surface Finish	Surface Roughness Device	0.05Ra	"
Mass	Balance	0.001g	QCI-111 ⁽⁵⁾
Dish Depth	Depth Micrometer	0.01mm	QCI-163
Density	Immersion	0.01g/cm ³	QCI-111

Table 2 IDR Pellet Characterization Summary (Average Value)

Fuel Type	Dish Depth (mm)	Chamfer Width (mm)	Surface Rough. (Ra)	Height (mm)	Diameter (mm)	Immer. Density (g/cm ³)	Mass (g)	Grain Size (μ m)
1.65%	0.19	.24	0.71	13.79	10.71	10.68	12.16	5.85
2.00%	0.24	.24	0.71	15.28	12.66	10.68	19.74	6.20
Accept. Criteria	0.011× ht. ± .07mm	0.25± 0.13mm	0.8μ m Ra Max.	L/D=1.4 Max.	10.715± 0.013 or 12.675± 0.013mm	10.60 g/cm ³ ± 0.15	-	5-30 μ m

3.2 ADU fuel pellets

Two kinds of ADU pellets were supplied by AECL. The fabrication and characterization of ADU pellets are recorded in the relevant AECL fabrication report.

3.3 Zircaloy Hardware

Bundle kits (Zircaloy-4 end plates, end plugs, and sheaths with brazed appendages) manufactured at KAERI earlier in 1996 were used for this fabrication campaign. All the zircaloy hardware were visually inspected and cleaned by air blowing prior to use. The fabrication data for the Zircaloy hardware used for this campaign are provided in KAERI technical report KF-FR-97-01⁽¹⁾.

4. Special Processes

Two special processes, end-closure welding and bundle assembly welding, were used during this fabrication campaign. Both special processes were confirmed to be qualified prior to the start of fabrication of the CANFLEX bundle.

4.1 Verification of End-Closure Welding

The quality of the end-closure welding process is determined by destructive examination of representative weld samples. These weld samples were produced in a manner identical to the final product, i.e., with the

same materials, using the same conditions and parameters as for production. The following subsections list the results of end-closure PC weld process verification.

4.1.1 Weld Rating

PC weld samples were sectioned and examined metallographically for weld soundness. The length of the weld line (minus any discontinuities) must be greater than the minimum tube wall thickness. This parameter, referred to as weld ratings, is reported as a percent of the minimum tube wall thickness. The end cap weld rating was defined in KAERI QCI (Quality Control Instruction) #731^[6] as follows:

$$\text{Weld Rating} = (\text{Total sound weld in zones} + 50\% \text{ of internal upset}) / \text{Sheath thickness}$$

The specified minimum is for a weld rating $\geq 100\%$. KAERI QCI #731 requires the soundness of weld rating to be judged either as 'Accepted' or 'Rejected'.

Three specimens for each type of fuel sheath were adopted for the qualification of the process even though large numbers of specimens were tested in advance to adjust the process. The following results were measured from end-closure PC weld samples:

- a. $\text{\O}11.5\text{mm}$: 3 sections tested; All accepted.
- b. $\text{\O}13.5\text{mm}$: 3 sections tested; All accepted

Therefore, the weld rating was acceptable for both diameters.

4.1.2 Peel Test

Peel testing consists of pulling the tube away from the end-cap on half sections of PC weld samples. The acceptance criterion is for failure to occur away from the weld.

- a. $\text{\O}11.5\text{ mm}$: 10 half sections tested,
Failure occurred away from the weld area; Accepted
- b. $\text{\O}13.5\text{ mm}$: 10 half sections tested,
Failure occurred away from the weld area; Accepted

4.2 Qualification of Bundle Assembly Welding

The strength of bundle assembly welds is shown through destructive testing of PC weld samples. Torque strengths of 49 specimens (thirty-nine 11.5mm PC and ten 13.5mm PC) tested during this campaign are presented in Table 3.

The relation between PC welds and actual end plate welds was presented in KAERI Process Qualification Report for the CANFLEX fuel assembly welding process, KF-TR-95-003 (Attachment 1) issued in May 18, 1995 and it specified control limit for PC welds torque strengths. The control limits were minimum 7.9 Nm and 6.3 Nm for 11.5mm and 13.5mm sheath, respectively. It means that the process cannot be qualified if any of the samples are not within the limit.

Table 3 shows that none of the values are below the control limits. Therefore, the assembly welding process is judged to be acceptable based on the control limit derived from the relation between PC welds and actual end plate welds.

Table 3 Result of Torque Strength Test

Type	Torque Strength					Average	Std. Dev.
Ø11.5mm	13	13.5	13.5	13.2	12.7	12.82Nm	0.68Nm
	12	12.7	12.1	12.6	13.5		
	11.7	12.5	12.1	11.6	12.3		
	12.4	12	12	11.3	13.4		
	12.5	13.5	13.2	13.7	13.2		
	12.2	13.7	13.4	13.7	13.2		
	13.6	12.2	12.7	12.6	13.2		
	13	13.5	14	13			
Ø13.5mm	7.8	7.5	8.3	8.2	7.9	8.37Nm	0.81Nm
	9.7	9.7	7.8	7.8	9		

5. Fabrication

5.1 In-Coming Inspection of ADU pellets supplied by AECL

Visual inspection for the ADU pellets supplied by AECL was performed. Defect pellets were segregated and prevented from use in fabrication.

5.2 CANLUB coating

The sheaths were CANLUB coated, cut to the finished length and weld-prep machined on each end in accordance with OI-608^[7], OI-609-2^[8] and OI-611-1^[9]. Nine and six samples of 11.5mm and of 13.5mm CANLUB coated tube were taken and the thickness was measured. The measured values are presented in Table 4.

Table 4 CANLUB Thickness

Ø11.5 mm				Ø13.5mm			
Smpl #	Bottom	Middle	Top	Smpl #	Bottom	Middle	Top
1	11.1	12.1	3.4	1	8.4	11.9	4.8
2	11.6	11.7	5.3	2	7.7	6.7	4.3
3	11.4	12.6	5.5	3	5.7	6.1	5.0
4	11.9	14.4	8.7	4	6.3	6.0	4.0
5	11.5	12.2	5.3	5	5.3	6.6	3.9
6	9.8	12.3	4.3	6	6.0	5.6	2.6
7	10.2	10.7	4.5				
8	10.8	14.3	4.9				
9	9.7	12.0	5.3				
Average		9.5 µm		Average		6 µm	
Std. Dev.		3.4 µm		Std. Dev.		2 µm	

H-gas content in the filling gas was calculated using the ideal gas state equation shown below.

$$P V = n R T$$

P and T represent the pressure and the temperature in the fuel element and the void volume, V was calculated using average dimensions in fabrication data as in attachment 2. Void volumes of the fuel elements are 1,306mm³ and 1,668mm³ for the Ø11.5 and the Ø13.5 fuel element, respectively. The filling gas contains 10 PPM of H-gas at most as shown in attachment 3 and 80% of the void volume, at least, was filled with He-gas. The calculation showed that the amount of H-gas was negligible compared to those in the pellet or CANLUB.

H-gas content in the pellet was not measured during the fabrication of CANFLEX-RU designed KAERI bundle. Therefore, it was predicted based on the data (Attachment 4) measured during the mass production of CANDU

fuels in the same fabrication process. Average amount of H-gas contained in the pellets is presented in Table 5 with its standard deviation.

In conclusion, total H-gas in the fuel element is 118.9 µg and is less than the H-gas limit of 600 µg as defined in QCI-722 ^[10].

Table 5. H-gas contents

Component	Average	Std. Deviation	Remarks
CANLUB	82.0 µg	24.5 µg	
Pellets	36.9 µg	19.0 µg	CANDU Data
Filling Gas	0.0 µg	-	
Total	118.9 µg		

5.2 Fuel Loading

All pellets were visually inspected during element loading. Pellet discs were cut from whole pellets and inserted second from the non-reference end pellet to achieve the specified stack length or the specified axial gaps. Details of the data obtained during fuel loading such as stack length, number of pellets etc. are listed in Table 6. Axial gap for each element was calculated based on the following formula.

$$\text{Axial Gap} = \text{Element length} - 2 \times \text{End-cap height} - \text{Stack length}$$

The end-cap height is taken by the average value which was calculated based on the fabrication data given in the attachments 16 and 17 of the fabrication report for the bundle kit[1]. The calculated L and S type end-cap heights were 4.075 mm and 5.065 mm, respectively. All the values of the axial gap are within the design requirement ($1\text{mm} \leq \text{clearance} \leq 3\text{mm}$) as defined in the drawing, CANFLEX-37000-1-1-GA-E, Rev.5 ^[11].

Diametral clearance was calculated using following formula.

$$\text{Diametral clearance} = \text{Sheath I.D} - \text{Pellet O.D}$$

Only average values are available for sheath I.D and pellet O.D. Therefore average diametral clearances were calculated and presented in Table 7 for 11.5 mm and 13.5 mm fuel sheath, respectively.

Table 6 Fuel loading data for bundle AKW

El #	Powder Type	Number of Pellet	Stack Length (mm)	Element Length (mm)	Axial Gap	UO2 (g)	Enr.U(g)	U235(g)
1	IDR	34	480.83	492.84	1.88	452	398.44	6.57
2	ADU	40	481.50	493.12	1.49	450	396.69	6.51
3	IDR	34	480.90	492.88	1.85	451	397.56	6.56
4	ADU	39	480.90	492.86	1.83	450	396.69	6.51
5	IDR	36	480.80	492.92	1.99	451	397.56	6.56
6	ADU	40	481.18	492.85	1.54	450	396.69	6.51
7	IDR	36	480.80	492.83	1.9	452	398.44	6.57
8	ADU	40	481.68	492.90	1.09	450	396.69	6.51
9	IDR	36	480.90	492.98	1.95	451	397.56	6.56
10	ADU	39	481.32	492.91	1.46	450	396.69	6.51
11	IDR	36	480.70	493.11	2.28	451	397.56	6.56
12	ADU	39	481.22	492.95	1.6	451	397.56	6.52
13	IDR	36	480.60	492.88	2.15	451	397.56	6.56
14	ADU	39	480.64	492.83	2.06	450	396.69	6.51
15	IDR	36	480.90	492.89	1.86	451	397.56	6.56
16	ADU	40	481.66	493.11	1.32	451	397.56	6.52
17	IDR	34	480.90	492.92	1.89	451	397.56	6.56
18	ADU	39	481.34	492.87	1.4	450	396.69	6.51
19	IDR	35	480.80	492.90	1.97	452	398.44	6.57
20	ADU	39	480.82	492.95	2	450	396.69	6.51
21	IDR	35	480.80	492.91	1.98	453	399.32	6.59
22	ADU	39	481.38	492.81	1.3	450	396.69	6.51
23	IDR	36	481.05	492.85	1.67	451	397.56	6.56
24	ADU	39	480.82	492.69	1.74	449	395.81	6.49
25	IDR	34	480.90	493.11	2.08	451	397.56	6.56
26	ADU	38	480.52	492.71	2.06	451	397.56	6.52
27	IDR	35	480.80	492.98	2.05	451	397.56	6.56
28	ADU	39	480.92	492.67	1.62	450	396.69	6.51
29	IDR	35	480.90	492.90	1.87	451	397.56	6.56
30	ADU	39	481.28	492.76	1.35	449	395.81	6.49
31	IDR	35	480.90	492.92	1.89	451	397.56	6.56
32	ADU	39	480.48	492.80	2.19	450	396.69	6.51
33	IDR	35	481.10	492.84	1.61	451	397.56	6.56
34	ADU	39	480.56	492.67	1.98	450	396.69	6.51
35	IDR	34	480.90	492.98	1.95	451	397.56	6.56
36	ADU	35	482.80	492.69	1.74	646	569.58	11.28
37	IDR	31	482.62	492.96	2.19	637	561.68	11.23
38	ADU	35	482.78	492.81	1.88	646	569.58	11.28
39	IDR	32	482.72	492.78	1.91	638	562.56	11.25
40	ADU	35	483.30	492.69	1.24	646	569.58	11.28
41	IDR	31	482.50	492.75	2.1	639	563.43	11.27
42	ADU	31	482.52	492.55	1.88	638	562.56	11.14
Ave11.5	-	37.08	480.96	492.88	1.92		0.00	-
Ave13.5	-	32.50	482.74	492.77	1.81		0.00	-
SUM	-	-	-	-	-	20264.5	17864	307.48

Table 7 Diametral clearance

Type	Sheath I.D	Pellet O.D	Diametral Clearance
Ø11.5mm sheath	10.786 mm	10.71 mm	0.076 mm
Ø13.5mm sheath	12.735 mm	12.66 mm	0.075 mm

The average value of sheath I.D was given in the attachment 3 and 4 of the fabrication report for the bundle kit, KF-FR-97-01 Rev.0^[1]. The average value of pellet O.D was given in the table 2 of the fabrication report, KF-FR-99-01 Rev.0^[2]. The clearance values are within the design requirement ($0.05\text{mm} \leq \text{clearance} \leq 0.13\text{mm}$) as defined in the drawing, CANFLEX-37000-1-1-GA-E, Rev.5.

5.3 Element End-Closure Welding

The fuel elements were fabricated by welding the first end cap and the second end cap to the tube according to the manufacturing operating instructions for end-closure welding^[12]. Qualification of end-closure welding for the two CANFLEX end-cap angles and diameters was conducted prior to the start of the campaign (See section 4.1).

5.4 Weld-flash Removal

The weld flash from the end-closure operation was removed on a low-speed lathe setup. Each element was checked against the specifications; no undercutting was observed, by visual examination, and the end-cap diameter was checked to be within specifications by micrometer.

5.5 Helium Leak Testing

All welded elements were subjected to helium leak testing prior to bundle assembly welding according to the manufacturing operating instruction for helium leak testing^[13]. The acceptance criteria is no indication above 10^{-7} cm³/s leak rate. No leaks were detected at the 5×10^{-8} cm³/s detection level and therefore the results were acceptable.

5.6 Assembly welding of Fuel Bundle

The process was qualified briefly by measuring the break-torques of end-closure welds for two endplate test specimens according to the appropriate sections of the operating instruction for the bundle assembly welding^[14]. Qualification of bundle assembly was conducted prior to the start of the campaign (See section 4.2).

Each element was visually inspected, as they were loaded into the assembly jig. Due to the different assembly weld upset, the two different element diameters were fabricated to slightly different length to ensure end-plate flatness. For bundle assembly, the reference-end end-plate was welded first, starting with the small diameter (outer and intermediate rings); then proceeding with the larger diameter elements. The bundle was then inverted and the non-reference end-plate welded, starting with the central and inner ring (larger diameter) elements, then proceeding with the outer ring (smaller diameter) elements.

5.7 Element Leak Test for the Assembled Bundle

Element leak test was conducted for the completed bundle after assembly welding according to the Manufacturing Operating Instructions for Helium Leak Testing. No leaks were detected at the 5×10^{-8} cm³/sec detection level.

5.8 Kinked-Tube Test

The kinked-tube test was performed and the bundle freely passed through the kinked-tube gauge under its own weight.

6. Nonconformance

No nonconformance was reported during this campaign.

7. Conclusion

The CANFLEX bundle was fabricated successfully at KAERI according to the QA provisions specified in references and as per relevant KAERI drawings and technical specification. The fabricated bundle will be used for power ramp irradiation testing in NRU reactor.


This report covers the fabrication activities performed at KAERI. Fabrication processes performed at AECL including fabrication of ADU pellets will be documented in a separate report.


8. References


- [1] Moon-Sung Cho, "Fabrication Report - CANFLEX Bundle Kit for Irradiation Test in NRU", KAERI Technical Report KF-FR-97-01 Rev.0, July 19, 1997.
- [2] Moon-Sung Cho, "Fabrication Report - Fabrication of CANFLEX-RU designed Bundle for Power Ramp Irradiation Test in NRU", KAERI Technical Report KF-FR-99-01 Rev.0, September 21, 1999.
- [3] "The Quality Assurance Manual for HWR Projects", KAERI, QAP May 1993
- [4] "Quality Control Instruction - Inspection of UO₂ Pellet Dimension and Surface", KAERI, QCI-163 Rev.2, June 18, 1996.
- [5] "Quality Control Instruction - Inspection of UO₂ Pellet Mass and Density", KAERI, QCI-111 Rev.8, February 1, 1994.
- [6] "Quality Control Instruction - Inspection of End-cap welding", KAERI, QCI-731 Rev.7, August 1, 1996.
- [7] "Operation Instruction - CANLUB Coating", KAERI, OI-608 Rev.10, July 13, 1996.
- [8] "Operation Instruction - Baking", KAERI, OI-609-2 Rev.7, June 19, 1996.
- [9] "Operation Instruction - Weld-prep Machining", KAERI, OI-611-1 Rev.5, March 3, 1992.
- [10] "Quality Control Instruction - Analysis of H-gas content in fuel element," QCI-727 Rev.3, KAERI, August 28, 1996.
- [11] Fuel bundle design drawing, "Joint AECL-KAERI CANFLEX 43 element bundle (CANDU-6) reference drawing," CANFLEX-37000-1-1-GA-E, Rev.5, KAERI/AECL, October 7, 1998.
- [12] "Operation Instruction - Element End-closure Welding", KAERI, OI-703-1 Rev.9, May 17, 1996.
- [13] "Operation Instruction - Helium Leak Testing", KAERI, OI-725 Rev.1, March 5, 1996.
- [14] "Operation Instruction - Bundle Assembly Welding", KAERI, OI-804-1 Rev.7, June 13, 1995.


Attachment 1. Process Qualification Report

부록 2. 개량형 핵연료 다발 용접 공정의 공정자격화 실험결과

 KAERI HWR FUEL DIV.	공정 자격 승인 보고서 PROCESS QUALIFICATION REPORT		
	문서번호 Doc. No.	개정번호 Rev. No.	날짜 Date
	KF-TR-95-003		95. 5. 18
제 목 CANFLEX fuel assembly welding Subject _____			
_____ 작 성 핵연료기술개발분야 C. H. Park (박춘호) 95. 5. 16 Prepared by Fuel Technology Development Dept. 날짜			
_____ 검 토 연료집합체제조분야책임자 H. S. Kim (김형수) 95. 5. 16 Reviewed by Manager, Fuel Fabrication Dept. 날짜			
_____ 검 토 핵연료품질관리분야책임자 K. A. Lee (이규암) 95. 5. 17 Reviewed by Manager, Quality Control Dept. 날짜			
_____ 승 인 핵연료기술분야책임자 C. B. Choi (최창범) 95. 5. 18 Approved by Manager, Fuel Technology Development Dept. 날짜			

 KAERI HWR FUEL DIV.	공정 자격 승인 보고서 PROCESS QUALIFICATION REPORT			페이지 Page
	문서번호 Doc. No. <i>KF-TR-95-003</i>	개정번호 Rev. No.	날짜 Date <i>95.5.18</i>	
핵연료기술 개발분야	제 목 : CANFLEX fuel assembly welding Subject			1 4
<p>1. Scope</p> <p>This report summarizes the process qualification of MKIV CANFLEX fuel assembly welding with EPW-2 welding machine.</p> <p>2. References</p> <p>The acceptance criteria, qualification procedures and welding operation, inspection instructions are outlined in the following documents.</p> <ul style="list-style-type: none"> • CANFLEX-TS-3700-001-P Product specification of CANFLEX fuel assembly • KAERI WP-80 Process specification of CANDU fuel assembly welding • KAERI OI-804 Operation instruction of CANDU fuel assembly welding • KAERI QCI-861 Dimensional inspection instruction of CANDU fuel assembly • KAERI QCI-841 Inspection instruction of weld torque strength 				

 KAERI HWR FUEL DIV.		공정 자격 승인 보고서 PROCESS QUALIFICATION REPORT		
		문서번호 Doc. No. KF-TR-95-003	개정번호 Rev. No.	날짜 Date 95.5.18
핵연료기술 개발분야	제 목 : CANFLEX fuel assembly welding Subject			2 4
<p>3. Qualification Procedure</p> <ul style="list-style-type: none"> • Process simulation specimen (PM set #1), 43 end caps were welded on MKIV end plate, was prepared and weld strengths were measured in accordance with QCI-841. • 43 fuel rods containing UO₂ pellets in graphite coated fuel sheaths were assembled into CANFLEX MKIV fuel bundle as per OI-804. The visual and dimensional integrity of the fuel bundle were inspected in accordanced with QCI-861. The torque strengths of end plate welds were measured. • Just after the assembly welding of test bundle, another process simulation specimens (PM set #2) was prepared and weld strengths were measured. 				

 KAERI HWR FUEL DIV.	공정 자격 승인 보고서 PROCESS QUALIFICATION REPORT			페이지 Page 3 4
	문서번호 Doc. No.	개정번호 Rev. No.	일자 Date	
핵연료기술 개발분야	KF-TR-95-003		95. 5. 18	
제 목 : CANFLEX fuel assembly welding Subject				
<p>4. Qualification results</p> <ul style="list-style-type: none"> Attached bundle inspection report shows inspection results of test bundle. The test bundle satisfied all the requirements except end plate height "E" dimension which was satisfied by filing of end plate. Table 1 shows the results of weld torque strengths of fuel bundle. The lowest weld strength was 8.2 N-m for outer-elements and 4.8 N-m for inner-elements. All the torque strengths in table 1 exceed the required torque strength i.e., 6.8 N-m for outer-elements and 4.6 N-m for inner-elements. In addition, these are satisfied with 95% confidence level as follows ; $\bar{X}_{outer} - 1.645 \sigma_{outer} = 8.6 \text{ N-m} > 6.8 \text{ N-m}$ $\bar{X}_{inner} - 1.645 \sigma_{inner} = 5.2 \text{ N-m} > 4.6 \text{ N-m}$ <p>Where \bar{X} : Average torque strength σ : Standard deviation</p>				


 KAERI HWR FUEL DIV.		공정 자격 승인 보고서 PROCESS QUALIFICATION REPORT		
		문서번호 Doc. No. KF-TR-95-003	개정번호 Rev. No.	날짜 Date 95. 5. 18
핵연료기술 개발분야	제 목 : CANFLEX fuel assembly welding Subject			4 4
<p> • Table 2 shows the torque strengths for two set of process simulation specimens to correlate process simulation welds with actual fuel assembly welds. The control limit evaluated by statistical treatment of table 1 and table 2 is shown in table 3. </p> <p> 5. Conclusion </p> <p> The torque strengths of the fuel bundle were higher than the required minimum of 6.8 N-m for outer-elements and 4.6 N-m for inner-elements with 95% confidence level. The external view and all the dimensional inspection items but end plate height were satisfied. "E" dimension could be satisfied by filing end plate welds. From these qualification results, it is found that fuel bundle welding process was qualified. </p>				

Table 1. Torque strengths of qualification fuel bundle

Location of outer element	Weld strength (N-m)		Location of inner element	Weld strength (N-m)	
	Monogram	Opposite		Monogram	Opposite
1	10.0	8.2	22	7.2	5.2
2	10.0	9.8	23	6.2	7.5
3	9.4	9.5	24	7.2	5.2
4	9.6	8.7	25	6.5	7.0
5	9.6	8.7	26	7.2	4.8
6	9.7	9.2	27	6.5	7.7
7	9.7	8.5	28	7.2	5.0
8	10.5	10.2	29	6.6	7.4
9	9.7	10.2	30	6.5	5.4
10	9.8	8.5	31	6.4	7.2
11	10.1	10.2	32	7.0	5.4
12	9.4	10.0	33	6.5	7.6
13	10.0	8.5	34	7.2	5.2
14	10.2	10.0	35	6.2	7.2
15	9.5	10.2	36	6.0	5.4
16	10.0	8.7	37	7.5	6.4
17	10.0	10.2	38	6.6	6.1
18	9.4	10.2	39	6.8	6.4
19	10.2	8.5	40	5.8	6.0
20	10.0	10.2	41	7.0	6.2
21	9.0	9.8	42	7.2	6.6
			43	7.0	5.3

Table 2. Torque strengths of process simulation (PS) specimens
in fuel bundle qualification welding

Location of outer element	Weld strength (N-m)		Location of inner element	Weld strength (N-m)	
	PS. Set#1	PS. Set#2		PS. Set#1	PS. Set#2
1	9.6	9.2	22	6.8	7.8
2	9.8	9.8	23	7.2	6.4
3	9.4	8.5	24	6.0	8.0
4	9.0	9.6	25	7.5	8.2
5	8.4	9.7	26	7.5	7.4
6	9.0	9.8	27	8.4	8.2
7	9.2	10.5	28	7.8	8.0
8	10.0	11.0	29	8.2	7.8
9	9.5	9.8	30	6.7	7.4
10	10.2	9.7	31	7.0	7.7
11	10.0	10.4	32	6.8	6.0
12	9.7	9.4	33	7.4	7.2
13	10.5	10.2	34	7.2	5.8
14	9.8	10.8	35	7.2	6.5
15	8.7	9.0	36	6.4	7.5
16	9.6	10.4	37	6.0	4.8
17	10.5	10.6	38	7.0	7.2
18	9.6	9.4	39	7.5	6.5
19	9.4	9.6	40	5.2	5.7
20	9.6	10.2	41	5.7	6.5
21	9.0	9.2	42	6.8	7.0
			43	6.6	6.7

Table 3. Evaluation of weld torque data of fuel bundle assembly welding

Average(\bar{X}) & standard deviation (σ)	\bar{X} (N-m)		σ		$\bar{X}-1.645\sigma$	
	Outer	Inner	Outer	Inner	Outer	Inner
Location of fuel element						
Experiment						
Process simulation Set #1	9.7	6.8	0.5	0.7	8.9	5.6
Fuel bundle qualification weld	9.6	6.5	0.6	0.8	8.6	5.2
Process simulation Set #2	10.0	6.7	0.6	0.8	9.0	5.4

※ Control limit

$$\text{outer element } 6.8 + | \bar{X}_{ps \text{ out}} - \bar{X}_{bundle.out} | + 1.645\sigma_{bundle.out} = 7.9$$

$$\text{Inner element } 4.5 + | \bar{X}_{ps \text{ inn}} - \bar{X}_{bundle.inn} | + 1.645\sigma_{bundle.inn} = 6.3$$

Where, $\bar{X}_{ps \text{ out}} = 9.7$

$$\bar{X}_{ps \text{ inn}} = 7.0$$



BUNDLE INSPECTION REPORT

KAERI

Bundle No. : TEST

No.	Characteristics	Monogram	Opposite	Remark
1	End Cap Angle (72° ± 1°)	OK	OK	
2	Visual Examination	OK	OK	
3	End Plate Perpendicularity (1.80 MAX.)	1.350	1.386	
4	End Plate Height (96.90 MAX.)	97.386	97.461 ¹⁾	
5	End Plate Waviness (0.56 MAX.)	0.350	0.290	
6	End Cap Height (100.46 MIN.)	100.514	100.532	
7	Droop (1.00 MIN.)	1.268	1.286	
8	Spacer Alignment	OK		
9	Kink-Tube Gauge	OK		
10	Element Length Variation (0.56 MAX.)	0.403		
11	Rubber Band Rule (Button)	OK		
12	Bundle Diameter (102.50 MAX.)	Upper B.P	Middle B.P	Lower B.P
		102.07	102.08	102.08
13	Bundle Length (495.30 ± 0.75)	495.90		
<p>Note : ¹⁾ "E" dimension of as-welded fuel bundle is a little higher than the specification. That can be satisfied by filing end plate welds.</p>				
Inspected by : <i>연진영</i>		Reviewed by : <i>park J</i>		

Attachment 2. Calculation of Element Void Volume



Korea Atomic Energy Research Institute

CANFLEX Fuel Development Project

P.O. Box 105, Yusong, Taejeon, 305-600, Korea

Tel. +82 42 868 2983/Fax. +82 42 868 8767

E-mail. hcsuk@nanum.kaeri.re.kr

KAERI-CANFLEX-CHO-00-005

To: H.C. Suk

June 16, 2000

Cc:

From: M.S. Cho

Calculation of Element Void Volume for CANFLEX Bundle AKW

In this memo, element void volumes of CANFLEX bundle AKW were calculated for use in a standard post-irradiation performance assessment and also to ensure that there are no unusual features that may affect power-ramp performance.

1. Void Volume of the $\varnothing 11.5$ Fuel Element

a. Pellet Dish and Chamfer

Pellet dish and chamfer volumes are assumed to be 1% of fuel stack volume and calculated as follows.

$$\begin{aligned}\text{Pellet Dish \& Chamfer Volume} &= 0.01\pi \times (\text{Pellet OD}/2)^2 \times \text{Stack Length} \\ &= 0.01\pi \times (10.71/2)^2 \times 480.96 \\ &= 433.3 \text{ mm}^3\end{aligned}$$

where, average pellet OD = 10.71 mm^[1], average stack length = 480.96 mm^[1].

b. Radial Gap Volume

Radial gap volume is calculated in accordance with the following equation.

$$\begin{aligned}\text{Radial gap volume} &= \pi \times ((\text{Sheath ID}/2)^2 - (\text{Pellet OD}/2)^2) \times \text{Stack Length} \\ &= \pi \times ((10.7858/2)^2 - (10.71/2)^2) \times 480.96 \\ &= 615.5 \text{ mm}^3\end{aligned}$$

where, average sheath ID = 10.7858^[1].

c. Axial Gap Volume

Axial gap is calculated as follows.


$$\begin{aligned}\text{Axial gap volume} &= \pi \times (\text{Sheath ID}/2)^2 \times \text{Axial Gap} \\ &= \pi \times (10.7858/2)^2 \times 1.92 \\ &= 175.4 \text{ mm}^3\end{aligned}$$

where, axial gap = 1.92 mm [1].

d. End-cap Void Volume


To calculate the volume of the end-cap void, it was sectioned into six parts as follows.

Sections #1, #2 and #3 are axisymmetric volumes and #4, #5 and #6 are ring volumes.



Please refer to the fabrication drawing CKF/FA/DW201-2 Rev.3^[2] for the $\varnothing 11.5$ end-cap dimensions used in the following calculation.

Part #1




$$h = 2.19 - 1.20 = 0.99 \text{ mm}$$

$$r = 6.04/2 - 0.5 = 2.52 \text{ mm}$$

$$\begin{aligned}\therefore V_1 &= 1/3 \pi r^2 h = \pi/3 (2.52)^2 (0.99) \\ &= 6.6 \text{ mm}^3\end{aligned}$$

Part #2




$$R = 0.5 \text{ mm}, \quad h = 0.5 \text{ mm}, \quad a = 2.52 \text{ mm}$$
$$x^2 + y^2 = 0.5^2, \quad x = (0.5^2 - y^2)^{1/2}$$

$$r = a + x$$
$$= 2.52 + (0.5^2 - y^2)^{1/2}$$

$$A_y = \pi r^2$$
$$= \pi [2.52 + (0.5^2 - y^2)^{1/2}]^2$$

$$\therefore V_2 = \int_0^{0.5} A_y dy$$
$$= 13.3 \text{ mm}^3$$


Part #3



$$r = 3.02 \text{ mm}, \quad h = 0.7 \text{ mm}$$

$$\therefore V_3 = \pi (3.02)^2 (0.7)$$
$$= 20.1 \text{ mm}^3$$

Part #4



$$a = 4.82 \text{ mm}, \quad b = 3.997 \text{ mm}, \quad R = 0.5 \text{ mm}$$

Part #4-1

$$\begin{aligned} r &= a + x \\ &= 4.82 + (0.5^2 - y^2)^{1/2} \end{aligned}$$

$$\begin{aligned} A_y &= \pi r^2 \\ &= \pi [4.82 + (0.5^2 - y^2)^{1/2}]^2 \end{aligned}$$

$$\begin{aligned} V_{4.1} &= \int_0^{0.5} A_y dy \\ &= 42.7 \text{ mm}^3 \end{aligned}$$

Part #4-2


$$\begin{aligned} r &= b + x \\ &= 3.997 + (0.5^2 - y^2)^{1/2} \end{aligned}$$

$$\begin{aligned} A_y &= \pi r^2 \\ &= \pi [3.997 + (0.5^2 - y^2)^{1/2}]^2 \end{aligned}$$

$$\begin{aligned} V_{4.2} &= \int_0^{0.5} A_y dy \\ &= 30.3 \text{ mm}^3 \end{aligned}$$

$$\begin{aligned} \therefore V_4 &= V_{4.1} - V_{4.2} \\ &= 12.4 \text{ mm}^3 \end{aligned}$$

Part #5



$$a = 5.32 \text{ mm}, \quad b = 3.997 \text{ mm}$$

Part #5-1


$$\begin{aligned} V_{5-1} &= \pi a^2 h = \pi (5.32)^2 (0.7) \\ &= 62.2 \text{ mm}^3 \end{aligned}$$

Part #5-2

$$\begin{aligned} V_{5-2} &= \pi b^2 h = \pi (3.997)^2 (0.7) \\ &= 35.1 \text{ mm}^3 \end{aligned}$$

$$\begin{aligned} \therefore V_5 &= V_{5-1} - V_{5-2} \\ &= 27.1 \text{ mm}^3 \end{aligned}$$

Part #6



$$a = 3.77 \text{ mm}, \quad h = 0.7 \text{ mm}, \quad b = h \tan 18^\circ = 0.227 \text{ mm}$$

$$\begin{aligned} r_y &= a + (b/h) y \\ &= 3.77 + (0.227/0.7) y \end{aligned}$$

$$A_y = \pi (r_y)^2$$

$$\begin{aligned} V_{\text{inner volume}} &= \int_0^{0.5} A_y dy \\ &= 33.2 \text{ mm}^3 \end{aligned}$$

$$\begin{aligned} V_{\text{cylinder}} &= \pi (3.997)^2 (0.7) \\ &= 35.1 \text{ mm}^3 \end{aligned}$$

$$\begin{aligned} \therefore V_6 &= V_{\text{cylinder}} - V_{\text{inner volume}} \\ &= 1.9 \text{ mm}^3 \end{aligned}$$

$$\begin{aligned} \therefore \text{\textcircled{11.5 End-cap Void Volume}} &= V_1 + V_2 + V_3 + V_4 + V_5 + V_6 \\ &= 81.4 \text{ mm}^3 \end{aligned}$$

$$\therefore \text{\textcircled{11.5 Fuel Element Void Volume}} = 1305.6 \text{ mm}^3$$

2. Void Volume of the Ø13.5 Fuel Element

a. Pellet Dish and Chamfer

Pellet dish and chamfer volumes are assumed to be 1% of fuel stack volume and calculated as follows.

$$\begin{aligned} \text{Pellet Dish \& Chamfer Volume} &= 0.01\pi \times (\text{Pellet OD}/2)^2 \times \text{Stack Length} \\ &= 0.01\pi \times (12.66/2)^2 \times 482.74 \\ &= 607.7 \text{ mm}^3 \end{aligned}$$

where, average pellet OD = 12.66 mm ^[1], average stack length = 482.74 mm ^[1].

b. Radial Gap Volume

Radial gap volume is calculated in accordance with the following equation.

$$\begin{aligned} \text{Radial gap volume} &= \pi \times ((\text{Sheath ID}/2)^2 - (\text{Pellet OD}/2)^2) \times \text{Stack Length} \\ &= \pi \times ((12.735/2)^2 - (12.66/2)^2) \times 482.74 \\ &= 722.1 \text{ mm}^3 \end{aligned}$$

where, average sheath ID = 12.735 ^[1].

c. Axial Gap Volume

Axial gap is calculated as follows.


$$\begin{aligned} \text{Axial gap volume} &= \pi \times (\text{Sheath ID}/2)^2 \times \text{Axial Gap} \\ &= \pi \times (12.735/2)^2 \times 1.81 \\ &= 230.6 \text{ mm}^3 \end{aligned}$$

where, axial gap = 1.81 mm ^[1].

d. End-cap Void Volume


To calculate the volume of the end-cap void, it was sectioned into six parts as follows.

Sections #1, #2 and #3 are axisymmetric volumes and #4, #5 and #6 are ring volumes.



Please refer to the fabrication drawing CKF/FA/DW202-3 Rev.0^[3] for the Ø13.5 end-cap dimensions used in the following calculation.

Part #1




$$h = 0.744 \text{ mm}$$

$$r = 3.5 \text{ mm}$$

$$\begin{aligned} \therefore V_1 &= \frac{1}{3} \pi r^2 h = \frac{\pi}{3} (3.5)^2 (0.744) \\ &= 9.5 \text{ mm}^3 \end{aligned}$$

Part #2



$$R = 0.5 \text{ mm}, \quad h = 0.5 \text{ mm}, \quad a = 3.5 \text{ mm}$$


$$x^2 + y^2 = 0.5^2, \quad x = (0.5^2 - y^2)^{1/2}$$

$$\begin{aligned} r &= a + x \\ &= 3.5 + (0.5^2 - y^2)^{1/2} \end{aligned}$$

$$\begin{aligned} A_y &= \pi r^2 \\ &= \pi [3.5 + (0.5^2 - y^2)^{1/2}]^2 \end{aligned}$$

$$\begin{aligned} \therefore V_2 &= \int_0^{0.5} A_y dy \\ &= 23.8 \text{ mm}^3 \end{aligned}$$


Part #3



$$r = 4 \text{ mm}, \quad h = 0.656 \text{ mm}$$

$$\begin{aligned} \therefore V_3 &= \pi (4)^2 (0.656) \\ &= 33.0 \text{ mm}^3 \end{aligned}$$

Part #4



$$a = 5.79 \text{ mm}, \quad b = 5.095 \text{ mm}, \quad R = 0.5 \text{ mm}$$

Part #4-1

$$\begin{aligned} r &= a + x \\ &= 5.79 + (0.5^2 - y^2)^{1/2} \end{aligned}$$

$$\begin{aligned} A_y &= \pi r^2 \\ &= \pi [5.79 + (0.5^2 - y^2)^{1/2}]^2 \end{aligned}$$

$$\begin{aligned} V_{4-1} &= \int_0^{0.5} A_y dy \\ &= 60.1 \text{ mm}^3 \end{aligned}$$

Part #4-2


$$\begin{aligned} r &= b + x \\ &= 5.095 + (0.5^2 - y^2)^{1/2} \end{aligned}$$

$$\begin{aligned} A_y &= \pi r^2 \\ &= \pi [5.095 + (0.5^2 - y^2)^{1/2}]^2 \end{aligned}$$

$$\begin{aligned} V_{4-2} &= \int_0^{0.5} A_y dy \\ &= 47.3 \text{ mm}^3 \end{aligned}$$

$$\begin{aligned} \therefore V_4 &= V_{4-1} - V_{4-2} \\ &= 12.8 \text{ mm}^3 \end{aligned}$$

Part #5



$$a = 6.29 \text{ mm}, \quad b = 5.095 \text{ mm}, \quad h = 0.63 \text{ mm}$$

Part #5-1


$$\begin{aligned} V_{5-1} &= \pi a^2 h = \pi (6.29)^2 (0.63) \\ &= 78.3 \text{ mm}^3 \end{aligned}$$

Part #5-2

$$\begin{aligned} V_{5-2} &= \pi a^2 h = \pi (5.095)^2 (0.63) \\ &= 51.4 \text{ mm}^3 \end{aligned}$$

$$\begin{aligned} \therefore V_5 &= V_{5-1} - V_{5-2} \\ &= 26.9 \text{ mm}^3 \end{aligned}$$

Part #6



$$a = 4.89 \text{ mm}, \quad h = 0.63 \text{ mm}, \quad b = h \tan 18^\circ = 0.205 \text{ mm}$$

$$\begin{aligned} r_y &= a + (b/h) y \\ &= 4.89 + (0.205/0.63) y \end{aligned}$$

$$A_y = \pi (r_y)^2$$

$$\begin{aligned} V_{\text{inner volume}} &= \int_0^{0.5} A_y dy \\ &= 49.3 \text{ mm}^3 \end{aligned}$$

$$\begin{aligned} V_{\text{cylinder}} &= \pi (4.89 + 0.205)^2 (0.63) \\ &= 51.4 \text{ mm}^3 \end{aligned}$$

$$\begin{aligned} \therefore V_6 &= V_{\text{cylinder}} - V_{\text{inner volume}} \\ &= 2.1 \text{ mm}^3 \end{aligned}$$

$$\begin{aligned} \therefore \text{Ø13.5 End-cap Void Volume} &= V_1 + V_2 + V_3 + V_4 + V_5 + V_6 \\ &= 108.1 \text{ mm}^3 \end{aligned}$$

$$\therefore \text{Ø13.5 Fuel Element Void Volume} = 1668.5 \text{ mm}^3$$

Reference

- [1] Moon-Sung Cho, Fabrication Report – Fabrication of CANFLEX-RU designed Bundle for Power Ramp Irradiation Test in NRU”, KAERI Technical Report KF-FR-99-01 Rev. 1, June 7, 2000.
- [2] Fuel bundle fabrication drawing, “End Cap,” CKF/FA/DW-201-2, Rev.3, KAERI, February 15, 1994.
- [3] Fuel bundle fabrication drawing, “End Cap,” CKF/FA/DW-202-3, Rev.0, KAERI, July 11, 1996.



Moon-Sung Cho

Attachment 3. Certificate of Analysis



유니온 카
 본 사 : 서울 : 중구
 TEL : (02) 2600-2600
 제1공장 : 경남 창원사
 TEL : (051) 2600-2600
 제2공장 : 경기도 화성
 TEL : (031) 2600-2600

가스분석성적서

(Certificate of Analysis)

Date : 1989 . 12. 19 .

주문자 : 한국에너지연구소
 Customer

분석번호 : GSI-GH-1959
 Anal. No.

SAMPLE CYLINDER NUMBER HK 00826

HE CONTAINER NUMBER 1930

용기번호 Cyl. No.	분석성분 Component	분석결과 Certified Composition	비고 Remark
------------------	-------------------	-------------------------------	--------------


HK 00826	HK 00341	HE(HP)	99.996% 이상
00920	00295		
00037	01667	H2	9 PPM
00513	00370		
00721	00061	N2	27 PPM
00330	00815		
00810	01175	HALOGENS	FREE
00314	00175		
00783		OTHERS(O2, H2O)	8-PPM

00101
 00326
 00072
 00616
 00635
 00710
 00257
 00298
 00238
 00160
 00177
 00933
 00527

분석일자 : 1989. 12. 16
 Date of Anal.

용기규격 : J
 Type of Cyl.

충전압력 : 135 (Kg/cm², 35°C)
 Filling Pressure


 승인자
 Approved



유니온가스
 본 사: 서울-중구... TEL: (02) ...
 제1공장: 경남 창원시... TEL: (055) ...
 제2공장: 경기도 화성시... TEL: (031) 726001

가스분석성적서

(Certificate of Analysis)

Date: 1989 . 9 . 25.

주문처: 한국에너지 연구소
 Customer

분석번호: GSL - GH - 1419
 Anal. No.

HE CONTAINER NUMBER : 1997

용기번호 Cyl. No.	분석성분 Component	분석결과 Certified Composition	비고 Remark
HK 00860 00547	HE(HP)	99.996% 이상 ✓	
01038 01577			
01086 00497	H2	10PPM 이하 ✓	
00195 00196			
00889 00363	N2	30PPM 이하 ✓	
00533 00708	HALOGENS	FREE ✓	
00190 00495			
00877 00393	OTHERS(O2, H2O) *	10PPM 이하 ✓	
00194 00111			
00317 00525			
00075 00083			
...107			
00320 00206			
01212 00756			
00121 00213			

확인
 품질관리
 9. 9. 26
[Signature]

분석일자: 1989.9.21.
 Date of Anal.

용기규격:
 Type of Cyl.

충전압력: 135 (Kg/cm², 35°C)
 Filling Pressure

[Signature]
 승인자
 Approved



유니온가스
 본사: 서울·중구
 TEL: (02) 2600-1111
 제1공장: 경남 창원시
 TEL: (051) 726-1111
 제2공장: 경기도 화성
 TEL: (031) 726-0000

가스분석성적서

(Certificate of Analysis)


Date: 1989. 7. 18.

주문처: 한국 에너지 연구소
 Customer

분석번호: GSL - GH - 1109
 Anal. No.

◦ HE CONTAINER NUMBER 1997.

용기번호 Cyl. No.	분석성분 Component	분석결과 Certified Composition	비고 Remark
HK 00673 01572	HE (HP)	MORE THAN 99.996%	✓
00202 00080	H2	10 PPM 이하	✓
01176 01301	N2	30 PPM 이하	✓
00265 00279	HALOGENS	FREE	✓
00162 00013	OTHERS	10 PPM 이하	✓
00357 00856			
00161 00485			
00189 00097			
00071 01048			
00292 00766			
00297 00868			
00337 00493			
00171 00613			
00471 00555			
00050 01410			



분석일자: 1989. 7. 14.
 Date of Anal.

용기규격: T
 Type of Cyl.

충전압력: 135 (Kg/cm², 35°C)
 Filling Pressure

승인자
 Approved



본 사 : 서울·동대문구... 108
 TEL: ...
 제1공장: 경남...
 TEL: ...
 제2공장: 경기도... 7-3
 TEL: ...

가 스 분 석 성 적 서
 (Certificate of Analysis)

Date : 1989 . 5 . 3 .

주 문 처 : 한국에너지 연구소
 Customer

분석번호 : GSL - GH - 0539
 Anal. No.

용 기 번 호 Cyl. No.	분 석 성 분 Component	분 석 결 과 Certified Composition	비 고 Remark
00531	HK 00957		
00804	00474	HE(HP)	99.996% 이상
01610	00884	O2	5 PPM 이하
00316	00402	H2O	5 PPM 이하
00181	00299	H2	10 PPM 이하
00256	00776	N2	30 PPM 이하
00406	01078	HAIOGENS	FREE
01355	00518		
00973			
00200			
00277			
00321			
00462			
00630			
01653			
00078			
00783			
01196			
01147			
00313			
00443			
9			

확인필
 품질관리실
 4.5.1.
 [Signature]

분석일자 : 1989. 4 . 30
 Date of filling

용기규격 : T
 Cyl. Type


충전압력 :
 Filling Pressure 135 (Kg/Cm²)

[Signature]
 승인자
 Approved

Attachment 4. Inspection Report


검 사 성 적 서
INSPECTION REPORT

일련 번호 IPH - 96-012

품질관리실 QC DEPT		검사명 : 연료봉(피복관, 소결체)내의 수소 함유량 분석 Title			페이지 Page	
<input checked="" type="checkbox"/> 연료봉 Kit 번호 : <input checked="" type="checkbox"/> 피복관 Batch 번호 : <input checked="" type="checkbox"/> 연료봉 Type :						
시편		항목	수소함유량	평균수소함유량	연료봉내 총수소 함유량	비 고
A	소결체	1	0.05 ^{ppm}	0.033 (avg)	N/A	Lot No. : 96 L 048 Batch No : U P 610 P
		2	.06			
		3	.06			
B	흑연도포 제거피복관	1				
		2				
	흑연도포 피복관	3				
		4				
		5				
		6				
C	장입 가스					
비 고 : * 흑연 도포층내의 평균 수소함유량 = (흑연도포 피복관의 평균 수소함유량 - 흑연도포제거 피복관의 평균 수소함유량) x 피복관 무게 ** 연료봉내 총 수소함유량 = A+B+C 검사기준 1. 연료봉내 총수소함유량 : 0.6 mg 이하 2. 피복관내 수소함유량 : 0.5 mg 이하 3. 소결체내 수소함유량 : 0.5 ppm 이하						
적용시방서 및 도면번호 : Spec. & Dwg. No. QCI-163, 722, 751			검사방법 : Deg. of Insp		판 정 : Verification 	
검사자 : Inspected by 진 정식			검사일자 : Date 96. 11. 28			
판정자 : Verified by 박 기			판정일자 : Date '96. 11. 28			


검 사 성 적 서
INSPECTION REPORT

일련 번호 1PH-p6-011

품질관리실 QC DEPT		검사명 : 연료봉(피복관, 소결체)내의 수소 함유량 분석 Title			페이지 Page	
<input checked="" type="checkbox"/> 연료봉 Kit 번호 : <input checked="" type="checkbox"/> 피복관 Batch 번호 : <input checked="" type="checkbox"/> 연료봉 Type :						
시편		항목	수소함유량	평균수소함유량	연료봉내 총수소 함유량	비 고
A	소결체	1	0.03 (ppm)	0.024 (mg)	N/A	Lot No. P6L041 Batch No. U P60P8
		2	.04			
		3	.05			
B	흑연도포 제거피복관	1				
		2				
	흑연도포 피복관	3				
		4				
		5				
		6				
C	장입 가스					
비 고 : * 흑연 도포층내의 평균 수소함유량 = (흑연도포 피복관의 평균 수소함유량 - 흑연도포제거 피복관의 평균 수소함유량) x 피복관 무게 ** 연료봉내 총 수소함유량 = A+B+C 검사기준 1. 연료봉내 총수소함유량 : 0.6 mg 이하 2. 피복관내 수소함유량 : 0.5 mg 이하 3. 소결체내 수소함유량 : 0.5 ppm 이하						
적용시방서 및 도면번호 : Spec. & Dwg. No. QCI-163, 722, 751			검사방법 : Deg. of Insp		판 정 : Verification 	
검사자 : Inspected by 진 정식			검사일자 : Date 1996. 11. 28			
판정자 : Verified by 박 정규			판정일자 : Date '96. 11. 28			

검 사 성 적 서
INSPECTION REPORT

일련 번호 IPH-P6-010

품질관리실 QC DEPT		검사명 : 연료봉(피복관, 소결체)내의 수소 함유량 분석 Title			페이지 Page	
<input checked="" type="checkbox"/> 연료봉 Kit 번호 : <input checked="" type="checkbox"/> 피복관 Batch 번호 : <input checked="" type="checkbox"/> 연료봉 Type :						
시편		항목	수소함유량	평균수소함유량	연료봉내 총수소 함유량	비 고
A	소결체	1	0.04 (ppm)	0.090 mg		Lot No : P5-LIP3 Batch No : UP6084
		2	0.35			
		3	0.09			
B	흑연도포 제거피복관	1		N/A	N/A	
		2				
	흑연도포 피복관	3				
		4				
		5				
		6				
C	장입 가스					
비 고 : * 흑연 도포층내의 평균 수소함유량 = (흑연도포 피복관의 평균 수소함유량 - 흑연도포제거 피복관의 평균 수소함유량) x 피복관 무게 ** 연료봉내 총 수소함유량 = A+B+C 검사기준 1. 연료봉내 총수소함유량 : 0.6 mg 이하 2. 피복관내 수소함유량 : 0.5 mg 이하 3. 소결체내 수소함유량 : 0.5 ppm 이하						
적용시방서 및 도면번호 : Spec. & Dwg. No. QCI-163, 722, 751			검사방법 : Deg. of Insp		판 정 : Verification 	
검 사 자 : Inspected by 진 정석			검사일자 : Date P6.10.17			
판 정 자 : Verified by 박 권우			판정일자 : Date 96.10.17			

검 사 성 적 서
INSPECTION REPORT

일련 번호 IPH - P6 - 00

품질관리실 QC DEPT	검사명 : 연료봉(피복관, 소결체)내의 수소 함유량 분석 Title	페이지 Page
------------------	--	-------------

- 연료봉 Kit 번호 :
 피복관 Batch 번호 :
 연료봉 Type :


시편		항목	수소함유량	평균수소함유량	연료봉내 총수소 함유량	비 고
A	소결체	1	0.04 (PPM)	0.035 mg		Lot No : P5L1P1
		2	0.06			
		3	0.08			
B	흑연도포 제거피복관	1		N/A	N/A	Batch No : U P6072 0
		2				
		3				
	흑연도포 피복관	4				
		5				
		6				
C	장입 가스					

비 고 :

* 흑연 도포층내의 평균 수소함유량 = (흑연도포 피복관의 평균 수소함유량 - 흑연도포제거
피복관의 평균 수소함유량) x 피복관 무게

** 연료봉내 총 수소함유량 = A+B+C

- 검사기준 1. 연료봉내 총수소함유량 : 0.6 mg 이하
 2. 피복관내 수소함유량 : 0.5 mg 이하
 3. 소결체내 수소함유량 : 0.5 ppm 이하

적용시방서 및 도면번호 : Spec. & Dwg. No. QCI-163, 722, 751	검사방법 : Deg. of Insp	판 정 : Verification 
검 사 자 : Inspected by <i>진 정익</i>	검사일자 : Date 96.10.17	
판 정 자 : Verified by <i>박 정우</i>	판정일자 : Date 96.10.17	

검 사 성 적 서
INSPECTION REPORT

일련 번호 IPH - P6 - 00

품질관리실 QC DEPT	검사명 : 연료봉(피복관, 소결체)내의 수소 함유량 분석 Title	페이지 Page
------------------	--	-------------

- 연료봉 Kit 번호 :
- 피복관 Batch 번호 :
- 연료봉 Type :


시편		항목	수소함유량	평균수소함유량	연료봉내 총수소 함유량	비 고
A	소결체	1	0.06 (PPM)	0.041 mg		Lot No : P5 L066 Batch No. : U P6002
		2	0.07			
		3	0.08			
B	흑연도포 제거피복관	1		N/A	N/A	
		2				
	흑연도포 피복관	3				
		4				
		5				
		6				
C	장입 가스					

비 고 :

* 흑연 도포층내의 평균 수소함유량 = (흑연도포 피복관의 평균 수소함유량 - 흑연도포제거 피복관의 평균 수소함유량) x 피복관 무게


** 연료봉내 총 수소함유량 = A+B+C

- 검사기준
1. 연료봉내 총수소함유량 : 0.6 mg 이하
 2. 피복관내 수소함유량 : 0.5 mg 이하
 3. 소결체내 수소함유량 : 0.5 ppm 이하

적용시방서 및 도면번호 : Spec. & Dwg. No. QCI-163, 722, 751	검사방법 : Deg. of Insp	판 정 : Verification 
검 사 자 : Inspected by <i>진 정목</i>	검사일자 : Date <i>P6.10.17</i>	
판 정 자 : Verified by <i>박 정우</i>	판정일자 : Date <i>96.10.17</i>	


검 사 성 적 서
INSPECTION REPORT

일련 번호 1PH-P6-00;

품질관리실 QC DEPT		검사명 : 연료봉(피복관, <u>소결체</u>)내의 수소 함유량 분석 Title			페이지 Page
<input checked="" type="checkbox"/> 연료봉 Kit 번호 : <input checked="" type="checkbox"/> 피복관 Batch 번호 : <input checked="" type="checkbox"/> 연료봉 Type :					
시편	항목	수소함유량	평균수소함유량	연료봉내 총수소 함유량	비 고
A	소결체	1	0.0p (ppm)	0.031 mg	Lot No. 95C098 Batch No: 4P5125 4P5125
		2	0.02		
		3	0.05		
B	흑연도포 제거피복관	1	N/A	N/A	
		2			
	흑연도포 피복관	3			
		4			
		5			
		6			
C	장입 가스				
비 고 : * 흑연 도포층내의 평균 수소함유량 = (흑연도포 피복관의 평균 수소함유량 - 흑연도포제거 피복관의 평균 수소함유량) x 피복관 무게 ** 연료봉내 총 수소함유량 = A+B+C 검사기준 1. 연료봉내 총수소함유량 : 0.6 mg 이하 2. 피복관내 수소함유량 : 0.5 mg 이하 3. 소결체내 수소함유량 : 0.5 ppm 이하					
적용시방서 및 도면번호 : Spec. & Dwg. No. QCI-163, 722, 751		검사방법 : Deg. of Insp		판 정 : Verification	
검 사 자 : Inspected by 진 정우 (인)		검사일자 : Date 96.10.17			
판 정 자 : Verified by 박 필규 (인)		판정일자 : Date 96.10.17			


검 사 성 적 서
INSPECTION REPORT

일련 번호 19496-006

품질관리실 QC DEPT		검사명 : 연료봉(피복관, <u>소결체</u>)내의 수소 함유량 분석 Title			페이지 Page
<input checked="" type="checkbox"/> 연료봉 Kit 번호 : <input checked="" type="checkbox"/> 피복관 Batch 번호 : <input checked="" type="checkbox"/> 연료봉 Type :					
항목 시편		수소함유량	평균수소함유량	연료봉내 총수소 함유량	비 고
A	소결체	1	0.02 ^{ppm}	0.022 mg	Lot NO. 952064 (U: 96054)
		2	0.03		
		3	0.06		
B	흑연도포 제거피복관	1	N/A	N/A	
		2			
	흑연도포 피복관	3			
		4			
		5			
		6			
C	장입 가스	N/A			
비 고 : * 흑연 도포층내의 평균 수소함유량 = (흑연도포 피복관의 평균 수소함유량 - 흑연도포제거 피복관의 평균 수소함유량) x 피복관 무게 ** 연료봉내 총 수소함유량 = A+B+C 검사기준 1. 연료봉내 총수소함유량 : 0.6 mg 이하 2. 피복관내 수소함유량 : 0.5 mg 이하 3. 소결체내 수소함유량 : 0.5 ppm 이하					
적용시방서 및 도면번호 : Spec. & Dwg. No. QCI-163, 722, 751			검사방법 : Deg. of Insp		판 정 : Verification 
검 사 자 : Inspected by 김 주 리			검사일자 : Date '96.8.21		
판 정 자 : Verified by 박 권 우			판정일자 : Date '96.8.21		

검 사 성 적 서
INSPECTION REPORT

일련 번호 1PH96-005

품질관리실 QC DEPT		검사명 : 연료봉(피복관, <u>소결체</u>)내의 수소 함유량 분석 Title			페이지 Page	
<input checked="" type="checkbox"/> 연료봉 Kit 번호 : <input checked="" type="checkbox"/> 피복관 Batch 번호 : <input checked="" type="checkbox"/> 연료봉 Type :						
시편		항목	수소함유량	평균수소함유량	연료봉내 총수소 함유량	비 고
A	소결체	1	0.06 ^{ppm}	0.056mg	MIA	Lot NO. 95L192 (4:96060)
		2	0.08 ^{ppm}			
		3	0.15 ^{ppm}			
B	흑연도포 제거피복관	1				
		2				
	흑연도포 피복관	3				
4						
5						
6						
C	장입 가스		MIA			
비 고 : * 흑연 도포층내의 평균 수소함유량 = (흑연도포 피복관의 평균 수소함유량 - 흑연도포제거 피복관의 평균 수소함유량) x 피복관 무게 ** 연료봉내 총 수소함유량 = A+B+C 검사기준 1. 연료봉내 총수소함유량 : 0.6 mg 이하 2. 피복관내 수소함유량 : 0.5 mg 이하 3. 소결체내 수소함유량 : 0.5 ppm 이하						
적용시방서 및 도면번호 : Spec. & Dwg. No. QCI-163, 722, 751			검사방법 : Deg. of Insp		판 정 : Verification 	
검 사 자 : Inspected by 김 후 리			검사일자 ; Date 96.8.21			
판 정 자 : Verified by 박 권 구			판정일자 : Date '96.8.21			


검 사 성 적 서
INSPECTION REPORT

일련 번호 279 96004

품질관리실 QC DEPT		검사명 : 연료봉(피복관, 소결체)내의 수소 함유량 분석 Title			페이지 Page		
<input checked="" type="checkbox"/> 연료봉 Kit 번호 : <input checked="" type="checkbox"/> 피복관 Batch 번호 : <input checked="" type="checkbox"/> 연료봉 Type :							
시편		항목	수소함유량	평균수소함유량	연료봉내 총수소 함유량	비 고	
A	소결체	1	0.104 ppm	0.1027 mg		Lot No: 95L198 (U: 96048)	
		2	0.104 "				
		3	0.106 "				
B	흑연도포 제거피복관	1		N/A			N/A
		2					
	흑연도포 피복관	3					
		4					
		5					
		6					
C	장입 가스		N/A				
비 고 : * 흑연 도포층내의 평균 수소함유량 = (흑연도포 제거 피복관의 평균 수소함유량 - 흑연도포제거 피복관의 평균 수소함유량) x 피복관 무게 ** 연료봉내 총 수소함유량 = A+B+C 검사기준 1. 연료봉내 총수소함유량 : 0.6 mg 이하 2. 피복관내 수소함유량 : 0.5 mg 이하 3. 소결체내 수소함유량 : 0.5 ppm 이하							
적용시방서 및 도면번호 : Spec. & Dwg. No. QCI-163, 722, 751			검사방법 : Deg. of Insp		판 정 자 Verification WR 합 격 국 립 표 준 관 리 원		
검 사 자 : Inspected by 김국희			검사일자 : Date '96. 7. 26				
판 정 자 : Verified by 박철우			판정일자 : Date '96. 7. 27				


검 사 성 적 서
INSPECTION REPORT

일련 번호 96-003

품질관리실 QC DEPT		검사명 : 연료봉(피복관, <u>소결체</u>)내의 수소 함유량 분석 Title			페이지 Page		
<input checked="" type="checkbox"/> 연료봉 Kit 번호 : <input checked="" type="checkbox"/> 피복관 Batch 번호 : <input checked="" type="checkbox"/> 연료봉 Type :							
시편		항목	수소함유량	평균수소함유량	연료봉내 총수소 함유량	비 고	
A	소결체	1	0.04 ppm	0.029 mg	N/A	Lot No: 95L196 (U: 96040)	
		2	0.07				
		3	0.04				
B	흑연도포 제거피복관	1		N/A			N/A
		2					
	흑연도포 피복관	3					
		4					
		5					
		6					
C	장입 가스	N/A					
비 고 : * 흑연 도포층내의 평균 수소함유량 = (흑연도포 피복관의 평균 수소함유량 - 흑연도포제거 피복관의 평균 수소함유량) x 피복관 무게 ** 연료봉내 총 수소함유량 = A+B+C 검사기준 1. 연료봉내 총수소함유량 : 0.6 mg 이하 2. 피복관내 수소함유량 : 0.5 mg 이하 3. 소결체내 수소함유량 : 0.5 ppm 이하							
적용시방서 및 도면번호 : Spec. & Dwg. No. QCI-163, 722, 751			검사방법 : Deg. of Insp		판 정 : Verification 		
검 사 자 : <u>김 숙 리</u> Inspected by			검사일자 : Date 96. 7. 26				
판 정 자 : <u>박 철 구</u> Verified by			판정일자 : Date 96. 7. 27				

검 사 성 적 서
INSPECTION REPORT

일련 번호 2P496-002

품질관리실 QC DEPT		검사명 : 연료봉(피복관, 소결체)내의 수소 함유량 분석 Title			페이지 Page	
<input checked="" type="checkbox"/> 연료봉 Kit 번호 : <input checked="" type="checkbox"/> 피복관 Batch 번호 : N/A <input checked="" type="checkbox"/> 연료봉 Type : W705						
시편		항목	수소함유량	평균수소함유량	연료봉내 총수소 함유량	비 고
A	소결체	1	0.05 ppm	0.029mg		Lot no: 95L194 (U96028)
		2	0.04 "			
		3	0.06 "			
B	흑연도포 제거피복관	1		N/A	N/A	
		2				
	흑연도포 피복관	3				
		4				
		5				
		6				
C	장입 가스	N/A				
비 고 : * 흑연 도포층내의 평균 수소함유량 = (흑연도포 피복관의 평균 수소함유량 - 흑연도포제거 피복관의 평균 수소함유량) x 피복관 무게 ** 연료봉내 총 수소함유량 = A+B+C 검사기준 1. 연료봉내 총수소함유량 : 0.6 mg 이하 2. 피복관내 수소함유량 : 0.5 mg 이하 3. 소결체내 수소함유량 : 0.5 ppm 이하						
적용시방서 및 도면번호 : Spec. & Dwg. No. QCI-163, 722, 751			검사방법 : Deg. of Insp		판 정 : Verified by 	
검 사 자 : Inspected by 진 정우			검사일자 : Date 96.6.21			
판 정 자 : Verified by 박 정우			판정일자 : Date 96.6.21			

검 사 성 적 서
INSPECTION REPORT

일련 번호 201496-001

품질관리실 QC DEPT		검사명 : 연료봉(피복관, <u>소결체</u>)내의 수소 함유량 분석 Title			페이지 Page	
<input checked="" type="checkbox"/> 연료봉 Kit 번호 : <input checked="" type="checkbox"/> 피복관 Batch 번호 : <i>N/A</i> <input checked="" type="checkbox"/> 연료봉 Type :						
시편		항목	수소함유량	평균수소함유량	연료봉내 총수소 함유량	비 고
A	소결체	1	<i>0.02 ppm</i>	<i>0.026mg</i>	<i>N/A</i>	<i>Lot NO: 95L195 (U96026)</i>
		2	<i>0.09 "</i>			
		3	<i>0.02 "</i>			
B	흑연도포 제거피복관	1		<i>N/A</i>		
		2				
	흑연도포 피복관	3				
4						
5						
6						
C	장입 가스	<i>N/A</i>				
비 고 : * 흑연 도포층내의 평균 수소함유량 = (흑연도포 피복관의 평균 수소함유량 - 흑연도포제거 피복관의 평균 수소함유량) x 피복관 무게 ** 연료봉내 총 수소함유량 = A+B+C 검사기준 1. 연료봉내 총수소함유량 : 0.6 mg 이하 2. 피복관내 수소함유량 : 0.5 mg 이하 3. 소결체내 수소함유량 : 0.5 ppm 이하						
적용시방서 및 도면번호 : Spec. & Dwg. No. QCI-163, 722, 751			검사방법 : Deg. of Insp		판 정 : Verification 합격 품질관리실	
검사자 : <i>진 정수</i> Inspected by			검사일자 : Date <i>96.6.21</i>			
판정자 : <i>박 권규</i> Verified by			판정일자 : Date <i>96.6.21</i>			



이산과우라늄 소결체 특성검사

KAERI
HWR FUEL DIV.

일련번호 : CISP -

95-004

넷취번호 : CFPTOL 넷취크기 : 4.110 EA 소결체증류 : S							페이지 1			
밀도 검사	직경 (mm)		시료 무게 (g)	크래들+시료 물속무게 (g)	크래들 물속무게 (g)	젖은시료 무게 (g)	물 의 도 (°C)	소결체 밀도 (g/cc)		
	상	중								
10.47~ 10.73 g/cc	10.88 88	10.80 18	12.9917 12.28	11.5890 6.084	0 0	N/A "	0.9973 "	10.77 .77		
판정:	89 91	18 80	12.9917 12.28	11.5890 6.084	0 0	N/A "	0.9973 "	10.77 .77		
O/U 비 검사	용기 무게 (g)	용기+시료 무게 /시료무게(g)	1차 산화후 용기+시료/시료 무게(g), WI1	2차 산화후 용기+시료/시료 무게(g), WI2	X (WI1- WI2)	O/U 비				
1.995~ 2.015										
판정:										
표면결함 검사	시료갯수	결함 내용	끝단칩	원주칩	핏트	이물질	크랙	젓평	기타	합계
	200EA		/							/
찾 수 및	직경		시료갯수 : 50 EA							
	10.710	표正正正正 正正正正正正正正 T	20 28 2	C: 0.004 x: 10.708 x: 10.713 S: 0.0023 U: 10.73 L: 10.70 Qu: 1.27 Ql: 5.83 Pu: 0 Pl: 0 P: 0 M: 1.71						
표면조도	길이 (mm)	직각도 (mm)	홈깊이 (mm)	어깨폭 (mm)	표면조도 (Ra, μm)					
	12.99 .94 12.07	0.02 .01 .02	0.20 .21 .20	0.24 .25 .23	0.18 .17 .17					
판정:	.02 .04	.01 01	.19 .20	.24 .24	.18 .18					
조 검 사	분말과립 유무		결정립 크기 (μm)			평균 결정립 크기 (μm)				
	무		P.P. P.8. 10.0 P.P			P.P. 0				
Fe 분석	<200 ppm		ppm		측정기기		기기번호		비고	
	없음				Electronic Balance		39090013			
판정:					Digimatic M/M		413996			
					Disc M/M		4426515			
장전길이	불량갯수/시료갯수 :				Dial Indicator		004221			
					Profile Projector		BP-30			
판정:					Surf. Rough Tester		02799			
					Digimatic Caliper		7001701			
검사자 : 권정식 12.99 P.P. 20					판정자 :					



이산과우라늄 소결체 생성검사

KAERI
HWR FUEL DIV.

일련번호 : CISP -

15 - 006

넷취번호 : CF 1506		넷취크기 : 14.708 EA		소결체증류 : L		페이지 1				
밀도 검사	직경 (mm)		시료 무게 (g)	크래들+시료 물속무게 (g)	크래들 물속무게 (g)	젖은시료 무게 (g)	물의 온도 (°C)	소결체 밀도 (g/cc)		
	상	중								
10.47~ 10.73 g/cc	10.88 86	10.84 84	13.649P 5040	12.3835 2527	0 0	N/A	0.9973	10.77 76		
판정:	86 86	82 81	6222 621P	35P4 358P	0 0			76 76		
O/U 비 검사	용기 무게 (g)	용기+시료 무게 /시료무게(g)		1차 산화후 용기+시료/시료 무게(g), WI1		2차 산화후 용기+시료/시료 무게(g), WI2		X (WI1- WI2)	O/U 비	
		1.995~ 2.015	20.2516 0514	43.7752 1156	12.4236 0642	44.3052 43.6316	13.9536 5802	44.3053 43.6316		13.9537 5802
판정:	1468 22.4660	5308 36.7522	3840 3062	44.0590 37.2774	9522 8314	44.0593 37.2776	9125 8316	0.0002 0.0002	0.0002 0.0002	
표면결합 검사	시료갯수	결합	끝단칩	원주칩	핏트	이물질	크랙	잼핑	기타	합계
	315 EA	내용	/							0
칩 수 및	직경		시료갯수 : 40 EA							
	10.710	표표표 표표표표 표	15 19 6							C: 0.004 x: 10.708 x: 10.7129 S: 0.0028 U: 10.73 L: 10.70 Qu: 6.11 Ql: 6.61 Pu: 0 Pl: 0 P: 0 M: 1.88
표면조도	길이 (mm)		직각도 (mm)		홈 깊이 (mm)		어깨 폭 (mm)		표면조도 (Ra, μm)	
	14.74 72 76 74 72	0.01 02 01 02 02	0.20 00 01 00 00	0.23 25 24 25 24					0.18 .16 .16 .16 .18	
판정:										
조각 검사	분말과립 유무		결정립 크기 (μm)				평균 결정립 크기 (μm)			
	없음									
Fe 분석	<200 ppm		ppm		측정기기		기기번호		비고	
	판정: 미량 없음				Electronic Balance		39090013			
장전길이	불량갯수/시료갯수 :				Digimatic M/M		413996			
	0/80				Disc M/M		4426515			
판정합격					Dial Indicator		004221			
					Profile Projector		BP-30			
				Surf. Rough. Tester		02799				
				Digimatic Caliper		7001701				
검사자 : 권경성 Under p.s.p. 20					판정자 :					

서 지 정 보 양 식

수행기관보고서번호	위탁기관보고서번호	표준보고서번호	INIS 주제코드		
KAERI/TR-1663/2000					
제목 / 부제	Fabrication of a CANFLEX-RU Designed Bundle for Power Ramp Irradiation Test in NRU				
연구책임자 및 부서명	조문성 (핵연료설계기술개발팀)				
연구자 및 부서명					
출판지	대전	발행기관	한국원자력연구소	발행년	2000.11
페이지	p.59	도표	있음(0), 없음()	크기	29× 21 Cm
참고사항					
비밀여부	공개(V), 대외비(), __ 급비밀		보고서종류	기술보고서	
연구위탁기관			계약 번호		
초록 (15-20줄내외)	<p>BDL-443 CANFLEX-RU AKW 다발은 캐나다 NRU 원자로에서의 출력급증시험에 사용될 목적으로 한국원자력연구소에서 제작되었다. 동 핵연료 다발에는 IDR 및 ADU 타입 핵연료 소결체가 한 칸씩 격봉 장입되었으며 외환 및 중환봉에는 1.65 wt% ²³⁵U를, 소결체, 내환 봉에는 2.00 wt% ²³⁵U 소결체를 장입하였다. 행거 바의 삽입을 위해 동 다발의 중심 봉을 제거하였다.</p> <p>IDR 소결체는 BNFL이 제공한 IDR 타입 UO₂ 분말을 사용하여 한국원자력연구소에서 제작하였으며 ADU 소결체는 AECL이 제작 공급하였다. 다발 키트 (지르칼로이-4 봉단 접합관, 봉단 마개, 피목관) 는 1996년 CANFLEX 핵연료 다발 제작을 위해 한국원자력연구소에서 제작한 것을 사용하였다. 동 다발은 관련 품질보증 규정과 도면 및 사양서 등에 따라 성공적으로 제작되었다. 본 보고서는 한국원자력연구소에서 수행한 제작업무에 대해서만 기술하였으며 ADU 소결체에 대한 제작업무는 AECL이 발행하는 별도의 보고서에 기술될 것이다.</p>				
키워드 (10단어내외)	CANFLEX, RU, Fuel, Fabrication, IDR, ADU, NRU, Power Ramp, Irradiation, AKW				

BIBLIOGRAPHIC INFORMATION SHEET

Performing Org. Report No.	Sponsoring Org. Report No.	Standard Report No.	INIS Subject Code
KAERI/TR-1663/2000			
Title/Subtitle	Fabrication of a CANFLEX-RU Designed Bundle for Power Ramp Irradiation Test in NRU		
Author and Department	Cho, Moon-Sung (Nuclear Fuel Development Team)		
Researcher and Department			
Publication Place	Taejon	Publisher	KAERI
			Publication Date
			2000.11
Page	p. 59	Ill. & Tab.	Yes(O), No ()
			Size
			29 × 21 Cm
Note			
Classified	Open(O), Restricted(), ___ Class Document	Report Type	Technical Report
Sponsoring Org.		Contract No.	
Abstract (15-20 Lines)	<p>The BDL-443 CANFLEX-RU bundle AKW was fabricated at Korea Atomic Energy Research Institute (KAERI) for power ramp irradiation testing in NRU reactor. The bundle was fabricated with IDR and ADU fuel pellets in adjacent elements and contains fuel pellets enriched to 1.65 wt% ²³⁵U in the outer and intermediate rings and also contains pellets enriched to 2.00 wt% ²³⁵U in the inner ring. This bundle does not have a center element to allow for insertion on a hanger bar.</p> <p>KAERI produced the IDR pellets with the IDR-source UO₂ powder supplied by BNFL. ADU pellets were fabricated and supplied by AECL. Bundle kits (Zircaloy-4 end plates, end plugs, and sheaths with brazed appendages) manufactured at KAERI earlier in 1996 were used for the fabrication of the bundle. The CANFLEX bundle was fabricated successfully at KAERI according to the QA provisions specified in references and as per relevant KAERI drawings and technical specification. This report covers the fabrication activities performed at KAERI. Fabrication processes performed at AECL will be documented in a separate report.</p>		
Subject Keywords (About 10 words)	CANFLEX, RU, Fuel, Fabrication, IDR, ADU, NRU, Power Ramp, Irradiation, AKW		