

Temelín PSA

Level 2



Ladislav Kučera

PSA Department

NPP Temelín, ČEZ, a.s.

Czech Republic

Presentation Overview

- ▲ Temelín NPP
- ▲ Temelín PSA
- ▲ Level 2 (1996)
- ▲ Level 2 Update (2003)
- ▲ Main Results
- ▲ Conclusions

Temelín Nuclear Power Plant

- ▲ Located in South Bohemia in the Czech Republic
- ▲ Construction started in 1987
- ▲ Initial Soviet design with four VVER-1000 units
- ▲ Standard RCS design, Czech design of BOP
- ▲ Decisions made after political changes in 1989:
 - ▲ Westinghouse I&C and Fuel
 - ▲ Only two units to be completed
 - ▲ Number of changes to increase safety
- ▲ Unit 1 trial operation started in July 10, 2002
- ▲ Unit 2 trial operation started in April 18, 2003

Temelín PSA

- ▲ First Temelín PSA performed in 1993-1996 with NUS and Czech subcontractors
- ▲ Number of conservative assumptions due to lack of information
- ▲ Two IPERS missions reviewed the first PSA (1995 and 1996)
- ▲ PSA Update performed in 2001-2003
- ▲ IPSART Mission for PSA Update performed in October 2003


PSA Level 2 (1995-1996)

▲ Level 2 performed by NUS and Temelin staff, with using UJV analyses made by STCP

▲ Results and conclusions:


- ▲ Robust large containment, resistant to overpressure failures (ultimate strength about 1 MPa)
- ▲ High frequency of Early failures due to:
 - ▲ Instrumentation channels through whole thickness of basemat
 - ▲ Pipe penetrations and equipment hatch near cavity
- ▲ High frequency of containment bypass given by SGTR frequency in Level 1
- ▲ High RCS pressure in time of vessel failure is beneficial
- ▲ Low frequency of Late failures
- ▲ Hydrogen burns and DCH not important

Temelín Reactor Building



PSA Level 2 (1996) (continued)

Basic Containment Failure Modes



CDF = $1.07E-04$ reactor-year⁻¹ (including Fire and Flood sequences)
LERF = $9.30E-05$ reactor-year⁻¹

PSA Level 2 Update (2002-2003)

- ▲ New MELCOR analyses available for Level 2 (phenomena, source terms, hydrogen recombiners)
- ▲ IPERS 1996 comments incorporated (DDT, door strength, containment isolation failure)
- ▲ SAMG measures assumed in Level 2 analysis:
 - ▲ Basemat penetration plugs
 - ▲ Corium barriers
- ▲ More detailed source terms evaluation
- ▲ RTARC calculations used for risk measure

Main Results of Level 2 Update

- ▲ Lower frequency of Early failures due to:
 - ▲ Basemat penetration plugs
 - ▲ Corium barriers
- ▲ Higher frequency of No failure and Late failures
- ▲ Numerical fractions of source terms developed for all STCs
- ▲ Integral dose for each STC calculated by RTARC code


Main Results of Level 2 (continued)

Source Term Categories

| STC | Description | Frequency |
|-----|--|-----------|
| 1. | No containment failure | 3.67E-06 |
| 2. | Large early containment failure; s prays OK | 1.86E-07 |
| 3. | Large early containment failure; no s prays | 1.17E-07 |
| 4. | Early containment leak; s prays OK | 7.52E-08 |
| 5. | Early containment leak; no s prays | 1.88E-08 |
| 6. | Early basemat melthrough, penetration failure; s prays OK | 8.68E-09 |
| 7. | Early basemat melthrough, penetration failure; no s prays | 1.72E-07 |
| 8. | Containment not isolated; s prays OK | 1.53E-07 |
| 9. | Containment not isolated; no s prays | 8.28E-08 |
| 10. | Late containment failure due to overpressure; s prays OK | 4.26E-09 |
| 11. | Late containment failure due to overpressure; no s prays | 4.35E-07 |
| 12. | Late containment failure due to overtemperature | 4.12E-07 |
| 13. | Late basemat melthrough; s prays OK | 2.84E-06 |
| 14. | Late basemat melthrough; no s prays | 3.20E-06 |
| 15. | SGTR with relief valves normally cycling | 2.72E-07 |
| 16. | SGTR with relief valves stuck in open position | 1.83E-07 |
| 17. | SGTR 40 - 100 mm with relief valves normally cycling | 3.14E-06 |
| 18. | SGTR 40 - 100 mm with relief valves stuck in open position | 1.74E-08 |
| 19. | ISLOCA 300 mm with aux. building effective | 3.52E-09 |
| 20. | ISLOCA 300 mm; aux. building ineffective | 1.57E-07 |

Main Results of Level 2 (continued)

Basic Containment Failure Modes



CDF = $1.51E-05$ reactor-year⁻¹ (without Fire and Flood sequences)

LERF = $4.04E-06$ reactor-year⁻¹

Main Results of Level 2 (continued)

▲ Dose calculations by RTARC showed up three most serious scenarios:

- ▲ STC 7 - Early basemat failure through instrumentation channels, no sprays
- ▲ STC 16 - SGTR with stuck relief valve
- ▲ STC 20 - ISLOCA

| STC | Frequency year ⁻¹ | Dose Sv | Relative Risk |
|-----------|---------------------------------|-----------------|------------------|
| 1 | 3.67E-06 | 1.46E-03 | 0.00% |
| 2 | 1.86E-07 | 4.95E+01 | 7.57% |
| 3 | 1.17E-07 | 5.36E+01 | 5.16% |
| 4 | 7.52E-08 | 1.04E-01 | 0.01% |
| 5 | 1.88E-08 | 1.90E+01 | 0.29% |
| 6 | 8.68E-09 | 4.65E+01 | 0.33% |
| 7 | 1.72E-07 | 1.60E+02 | 22.63% |
| 8 | 1.53E-07 | 4.22E+01 | 5.31% |
| 9 | 8.28E-08 | 5.87E+01 | 4.00% |
| 10 | 4.26E-09 | 9.39E-03 | 0.00% |
| 11 | 4.35E-07 | 3.24E-02 | 0.01% |
| 12 | 4.12E-07 | 2.61E-02 | 0.01% |
| 13 | 2.84E-06 | 2.57E-02 | 0.06% |
| 14 | 3.20E-06 | 3.39E-02 | 0.09% |
| 15 | 2.72E-07 | 2.09E-01 | 0.05% |
| 16 | 1.83E-07 | 1.62E+02 | 24.38% |
| 17 | 3.14E-06 | 1.79E+00 | 4.62% |
| 18 | 1.74E-08 | 2.13E+02 | 3.05% |
| 19 | 3.52E-09 | 3.49E+01 | 0.10% |
| 20 | 1.57E-07 | 1.73E+02 | 22.33% |

Conclusions of Level 2

- ▲ Containment failures „moved“ from „Early“ to „Late“ categories thanks to SAMG measures (penetration plugs, corium barriers)
- ▲ Low frequency of overpressure failures
- ▲ Hydrogen recombiners important both for Early and Late containment failures
- ▲ Uncertainty of source terms due to insufficient and inconsistent analyses data
- ▲ One early failure and two bypass scenarios found to be most important from frequency/radiological consequences viewpoint