
NPP Bohunice - radiation protection indicators for last 10 years.

Tibor Rapant, NPP Jaslovské Bohunice

Selected radiation protection indicators of NPP Bohunice operation are published in poster radioactive discharges to atmosphere and hydrosphere, personal doses, outage doses, maximum environmental doses. Limited parameters are also compared with authorized year limits.

NPP V-1




Note:

aerosols - 2000 - increase caused by 140-days GO and reconstruction of reactor no.1 noble gases, iodine ¹³¹I - 2002, 2004 - increase caused by fuel element leakage of reactor no.2

NPP V-2

Gaseous discharges

Liquid effluents



Note:


aerosols, iodine ¹³¹I - 1995-1997 - aerosols and iodine discharges were measured by device Kalina with high MDA

- 1998 - from february 1998 discharges were laboratory gamaspectrometry analyzed which gave rise to very low MDA

iodine 131 I - 2002 - increase caused by fuel element leakage of reactor no.3

strontium - 1998 - increase measured during GO of reactor no.4

Note:




Doses at NPP Bohunice


182

1997 - 2000 - reconstruction of reactors no.1 and no.2 gave rise to increase of number of monitored workers and collective dose on NPP V-1.

Dose distribution at NPP Bohunice



Doses at NPP Bohunice - outages



Note:

TGO - standard outage

RGO - extended outage REKO - reconstruction

Environmental doses at NPP Bohunice

Maximum Individual effective dose - ortificit age group. (Values calculated with gaseous discharges and figurd efficients from SE EBO and SE V Locality - 1995-1998 Zhovce, 1999-2002 Malzenice, 2003-2004 Pecenady. 2006 and 2004 2-7 -E [nSv] atmosphere 143,58 456,70 369,45 157,37 85,61 203,50 221,78 224,70 93,28 149,17 🖬 hydrosphere 143,58 456,70 369,45 157,37 85,61 203,50 221,78 224,70 93,28 149,17 together year

Note:

Since 1995 all liquid effluents from NPP are released by pipe system Sokoman to river Váh which gave rise to zero hydrosphere individual dose near NPP.