

16th AER Symposium of AER on WWER Reactor Physic and Reactor safety
September 25-29,2006,Bratislava,Slovakia

Utilisation of Gd II Fuel Assemblies at Bohunice NPP Unit 3, 4


O. Grežďo, M. Kačmar

9/2006

Contents

1. Brief summary of Bohunice V-2 (3. and 4. unit) NPP fuel cycle
2. Gd II fuel licensing
3. Consequences of Gd II fuel utilization
4. First experience with new fuel with burnable absorber and upgraded core monitoring system
5. Conclusion

1. Brief summary of Bohunice V-2 (3. and 4. unit) NPP fuel cycle

In the fig. 1.  you can see evolution of nuclear fuel cycle in Bohunice V-2 up to the moment. This changes results in better nuclear fuel cycle economy and reduction of neutron flux on reactor vessel.

The close changes of fuel cycle is expected in connection with increase of the reactor power:

-104% (2008 3.unit)

-105%(2009 4.unit)

-107%(2010 3 and 4. unit).

Number of leakage assemblies is in the fig.2 

2.Gd II fuel licensing for 3. and 4. unit Bohunice NPP

Choice of supplier and fuel licensing took approximately four years. Regulatory authority accept new fuel 26 months after contract was signed. If we want prepare new contract in 2011 year(current contract is valid to 2010), we dont have a lot of time.

3. Consequences of Gd II fuel utilization

3.1 Change of operational limits and conditions


Power distribution

both $k_q \leq 1,40 \frac{N_{dov}}{N}$ and $k_q \leq 1,8$ - for 1.generation fuel


both $k_r \leq 1,60 \frac{N_{dov}}{N}$ and $k_r \leq 2,2$ - for 1.generation fuel

both $k_r \leq 1,66 \frac{N_{dov}}{N}$ and $k_r \leq 2,2$ - for 2.generation fuel

Maximal linear power of fuel element



Working CA group position



3.2 Core monitoring system(CMS) SCORPIO upgrade

System SCORPIO evaluates signals from temperature and neutron detectors placed in the reactor and gives information about the core power distribution to the reactor operator and physicists.

Main functions of CMS SCORPIO:

- Processing of measurement data
- Temperature sensor calibration
- 3-D power distribution reconstruction
- Limit checking and thermal margin calculation
- Calculation of margin to PCI
- Primary circuit coolant activity monitoring
- Reactivity measurement during start-up
- Predictive mode and strategic planning
- Automated set up for new cycle
- Data archiving

Core follow mode provides:

- Monitoring of measured and calculating parameters of reactor, fuel assemblies and fuel pins
- Checking the status of the in-core detectors
- Evaluation of margins to operational and safety limits and alarm indication
- Displaying of the trend curves of selected parameters, display of detailed core map
- Displaying the status of each modules
- Archiving of selected parameters in the user forms

Core predictive mode (strategy generator)

Core predictive mode provides information for optimization of expected power changes for the 168 hours ahead

System calculates:

- minimal changes of boron acid concentration during power transients
- power distribution during expected power changes
- critical boron concentration
- control fuel assembly critical position
- shutdown boron concentration

Main monitoring (limits) parameters of core:



- Outlet temperature of fuel assemblies
- Coolant temperature rises in the fuel assemblies
- Radial assembly-wise power peaking factors k_q
- Pin-wise power peaking factors k_r
- linear power q_{lin}

Other monitoring parameters of core:

- Nodal power peaking factors k_v
- Nuclear heat flux hot channel factors F_q
- Departure from nucleate boiling ratio DNBR
- Margin of subchannel output coolant temperature to the saturation temperature t_{SAT}

CMS Scorpio software upgrade

- Change from 20/40 calculation point along the height of core to 42 calculation point.
- Changes of neutron- physical model as a result of geometric and material changes.
- Implementation of diffusion libraries for new fuel type.
- KRITEX(Reactivity measurement during start-up) module changes.
- STRATEGIC GENERATOR(Predictive mode) module changes
- Add an option to do correction of assemblies outlet temperature in dependence on power distribution profile in Gd II assembly(This option don't use up to the moment).
- Possibility of manual set CA position.

4. First experience with new fuel with burnable absorber and upgraded core monitoring system




Following figures and tables summarize first comparison between theoretical and „experimental“ values.


„experimental“ values – experimental values measured during physical start-up (nonstandard measure system)
– values calculated with CMS SCORPIO (MOBYDICK)

theoretical values - values calculated with BIPR-7

4.1 Operation with Gd II fuel 22.cycle 4.unit Bohunice NPP

Core loading pattern

$\frac{\text{number of FA}}{\text{number of CA}}$	FRESH FUEL	1st YEAR	2nd YEAR	3rd YEAR	4th YEAR	5th YEAR
 ENRICHMENT 3,82%	$\frac{0}{0}$	$\frac{66}{12}$	$\frac{66}{6}$	$\frac{66}{12}$	$\frac{54}{1}$	$\frac{0}{0}$
 ENRICHMENT 4,25% + Gd ₂ O ₃	$\frac{60}{0}$	$\frac{0}{0}$	$\frac{0}{0}$	$\frac{0}{0}$	$\frac{0}{0}$	$\frac{0}{0}$
 ENRICHMENT 3,84% + Gd ₂ O ₃	$\frac{0}{6}$	$\frac{0}{0}$	$\frac{0}{0}$	$\frac{0}{0}$	$\frac{0}{0}$	$\frac{0}{0}$




Physical start-up results

Duration: from 13.7.2006 9.24 to 16.7.2006 3.00


		Theoretical	Experimental	Deviation	Criteria
Critical concentration H3BO3 in PC [g/kg]		7.78	7.55	-0.22	±0.4 g/kg
Asymetry coefficients	min	1	0.964	-0.036	-7%rel
	max	1	1.064	0.064	7%rel
Asyptotic period	min	-	-	-13.40%	-30%rel
	max	-	-	6.40%	30%rel
Temperature reactivity coefficient [$10^{-2}\%/^{\circ}\text{C}$]	200 [$^{\circ}\text{C}$]	-0.61	-0.74	0.13	$\pm 0.4 \cdot 10^{-2} \%/^{\circ}\text{C}$
	210	-0.74	-0.85	0.11	$\pm 0.4 \cdot 10^{-2} \%/^{\circ}\text{C}$
	220	-0.87	-0.97	0.10	$\pm 0.4 \cdot 10^{-2} \%/^{\circ}\text{C}$
	230	-0.99	-1.11	0.12	$\pm 0.4 \cdot 10^{-2} \%/^{\circ}\text{C}$
	240	-1.12	-1.26	0.14	$\pm 0.4 \cdot 10^{-2} \%/^{\circ}\text{C}$
	250	-1.25	-1.44	0.19	$\pm 0.4 \cdot 10^{-2} \%/^{\circ}\text{C}$
	260	-1.38	-1.65	0.27	$\pm 0.4 \cdot 10^{-2} \%/^{\circ}\text{C}$
CA system total worth [%]		12.5	12.34	1.40%	±21%rel
CA system total worth with CA 03-46 stuck[%]		8.26	7.68	7.00%	±20%rel
Worth of "ejected" CA 06-49 [%]		0.52	0.59	-11.90%	±20%rel
CA drop time [s]		8 to 13	10.2 to 11.6	-	from 8 to 13 s
Boron acid worth [%kg/g]		-1.48	-1.44	2.80%	±17%rel
Worth of working CA [%]		0.81	0.87	-6.90%	±17%rel
Isothermal state	TČ	-	< 0.5	< 0.5	< 0.5
	OT	-	< 0.2	< 0.2	< 0.2

Graph of boron acid concentration




Maximal radial assembly-wise power peaking factors k_q

Comparison BIPR-SCORPIO




Pin-wise power peaking factors kr

Comparison BIPR-SCORPIO






Maximal linear power q_{lin}



Comparison between experimental(SCORPIO) and teoretical(BIPR) group kq and relative deviation 2.eff.days

20.7.2006 Tef = 2.3 eff. days N = 1373 MW CA6 = 240 cm






20.7.2006

Tef = 2.3 eff. days




N = 1373 MW

CA6 = 240 cm



Comparison between "experimental"(SCORPIO) and teoretical(BIPR) group kr and relative deviation 2.eff.days

20.7.2006 Tef = 2.3 eff.days NR = 1373 MW h6 = 240 cm




20.7.2006


Tef = 2.3 eff.days

NR = 1373 MW

h6 = 240 cm




GD II fuel
profil.fuel



number of group

rel. deviation = $(kr_{SCORPIO} / kr_{BIPR} - 1) * 100$






Comparison between experimental(SCORPIO) and teoretical(BIPR) group kq and relative deviation 40.eff.days

27.8.2006

Tef = 40,4 eff. days

NR = 1373 MW

h6 = 225 cm






20.7.2006

Tef = 2.3 eff. days




N = 1373 MW

CA6 = 240 cm



Comparison between "experimental"(SCORPIO) and teoretical(BIPR) group kr and relative deviation 40.eff.days

27.8.2006 Tef = 40,4 eff.days NR = 1373 MW h6 = 225 cm





27.8.2006

Tef = 40,4 eff.days

NR = 1373 MW


h6 = 225 cm



4.1 Operation with Gd II fuel 23.cycle 3.unit Bohunice NPP

Core loading pattern

	FRESH FUEL	1st YEAR	2nd YEAR	3rd YEAR	4th YEAR	5th YEAR
number of FA number of CA						
ENRICHMENT 3,82%	$\frac{0}{0}$	$\frac{60}{12}$	$\frac{72}{6}$	$\frac{54}{12}$	$\frac{66}{1}$	$\frac{0}{0}$
ENRICHMENT 4,25%	$\frac{60}{0}$	$\frac{0}{0}$	$\frac{0}{0}$	$\frac{0}{0}$	$\frac{0}{0}$	$\frac{0}{0}$
ENRICHMENT 3,84%	$\frac{0}{6}$	$\frac{0}{0}$	$\frac{0}{0}$	$\frac{0}{0}$	$\frac{0}{0}$	$\frac{0}{0}$




Physical start-up results

Duration: from 2.9.2006 10.26 to 4.9.2006 5.10

		Theoretical	Experimental	Deviation	Criteria
Critical concentration H3BO3 in PC [g/kg]		7.62	7.9	0.28	±0.4 g/kg
Asymetry coefficients	min	1	0.981	-0.019	-7%rel
	max	1	1.024	0.024	7%rel
Asyptotic period	min	-	-	-10.70%	-30%rel
	max	-	-	14.70%	30%rel
Temperature reactivity coefficient [$10^{-2}\%/^{\circ}\text{C}$]	200 [$^{\circ}\text{C}$]	-0.77	-0.77	0	$\pm 0.4 \cdot 10^{-2} \%/^{\circ}\text{C}$
	210	-0.88	-0.94	0.06	$\pm 0.4 \cdot 10^{-2} \%/^{\circ}\text{C}$
	220	-1.01	-1.11	0.1	$\pm 0.4 \cdot 10^{-2} \%/^{\circ}\text{C}$
	230	-1.16	-1.28	0.12	$\pm 0.4 \cdot 10^{-2} \%/^{\circ}\text{C}$
	240	-1.32	-1.45	0.13	$\pm 0.4 \cdot 10^{-2} \%/^{\circ}\text{C}$
	250	-1.5	-1.62	0.12	$\pm 0.4 \cdot 10^{-2} \%/^{\circ}\text{C}$
	260	-1.69	-1.79	0.1	$\pm 0.4 \cdot 10^{-2} \%/^{\circ}\text{C}$
CA system total worth [%]		10.52	11	4.60%	±21%rel
CA system total worth with CA 03-46 stuck[%]		7.43	7.74	4.20%	±20%rel
Worth of "ejected" CA 06-49 [%]		0.45	0.42	-6.70%	±20%rel
CA drop time [s]		8 to 13	10.2 to 11.6	-	from 8 to 13 s
Boron acid worth [%kg/g]		-1.47	-1.35	8.20%	±17%rel
Worth of working CA [%]		0.83	0.94	-13.30%	±17%rel
Isothermal state	TC	-	< 0.5	< 0.5	< 0.5
	OT	-	< 0.2	< 0.2	< 0.2


Maximal radial assembly-wise power peaking factors kq

Comparision BIPR-SCORPIO




Pin-wise power peaking factors kr

Comparison BIPR-SCORPIO



Maximal linear power q_{lin}



Comparison between experimental(SCORPIO) and teoretical(BIPR) group kq and relative deviation




5.eff.days




10.9.2006

Tef = 4.9 eff.days

NR = 1375 MW

h6 = 220 cm





Comparison between "experimental"(SCORPIO) and teoretical(BIPR) group kr and relative deviation




5.eff.days

10.9.2006

Tef = 4.9 eff.days

NR = 1375 MW

h6 = 220 cm





10.9.2006

Tef = 4.9 eff.days

NR = 1375 MW

h6 = 220 cm



5. Conclusion

- The close changes of fuel cycle in Bohunice V-2 NPP is expected in connection with increase of the reactor power to 107% in 2010
- Choice of supplier and fuel licensing took approximately four years.
- Differences between theoretical (BIPR7) and experimental values measured during physical start-up are not significant.
- Differences between theoretical (BIPR7) and „experimental“ (SCORPIO-MOBYDICK) values are not significant up to the moment.

THANK YOU FOR YOU ATTENTION!

Presentation prepare:

O.Grežďo


References:

M.Antal,M.Kačmar – fuel cycles,licensing

V.Mráz – 4.unit,SCORPIO

O.Grežďo – 3.unit

Fig. 1 Summary of Bohunice V-2 NPP fuel cycle. Weight of fresh fuel for FPD and burn up of discharged fuel.



4		1	2NZ	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
3	1N	2Z	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25
unit/year	1984	1985	1986	1987	1988	1989	1990	1991	1992	1993	1994	1995	1996	1997	1998	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008

DESIGN LOADINGS

Z- TRANSIT TO LOW LEAKAGE

N- TRANSIT TO NON-DESIGN

4Y- TRANSIT TO 4-YEAR CYCLES

NUMBER OF CYCLE

PF- PROFILED FUEL 5Y- 5YEAR CYCLE

Gd2 - Gd 2 fuel 6Y- 6YEAR CYCLE

Fig.2 Number of leakage FA – 3. and 4.UNIT




Fig 3. Screen - Power distribution (system tests)

Rozloženie výkonu

os2-1 18/05/06 12:10:44

Blok: **1**

Prac. st.: **6**

Tlak. spád: **0.249**

Tstr. PO: **281.8**

HRK 8 sk.: **200.0**

Výkon: **1405**

Efektívny čas: **2.0**

T slučiek: **29.1 30.6 31.3 30.2 29.7 30.0**

29.52

266.75

102.2

30.14

SCORPIO

Snim

Limity

Anom.

Pes

Tnom

Mapa AZ

Info

- Kompenz. krabice
- HRK
- Limity

Axiálna distribúcia vybranej kazety:

Suradnica: 08-S3 Číslo KNI: 12
Šestina: 1 Číslo skupiny: 37

Parametre:

Hodnota Kv

Zvolený parameter:

Kazetový koeficient nevyrovnania Kq	1.06
Prúťkový koeficient nevyrovnania Kr	1.17
Objemový koeficient nevyrovnania Kv	1.29
Faktor horúceho kanála Fq	1.43

Šest.1:	Šest.2:	Šest.3:	Šest.4:	Šest.5:	Šest.6:	Stred.:
1.17	1.19	1.00	1.19	1.17	1.17	1.00

Prech. proces Limity Vadné snímače SCORPIO Anomálie Teploty Rozl. výkonu PES PEPA

Výpočet krit. Symetria DT Zák. parametre

Fig.4 Screen – Strategy generator



Fig.5 Screen – Limit checking(system test)

