


# Fuel Element Designs For Achieving High Burnups in 220 MWe Indian PHWRs


P.N.Prasad, Rahul Mani Tripathi,  
K.P.Dwivedi, A.N.Kumar

Nuclear Power Corporation of India Ltd,  
Mumbai, India

# Nuclear Power Plants In Operation in INDIA




# Nuclear Power Plants Under Construction



# Future Plan

- PHWRs 8 units of 700 MWe
- FBRs 4 units of 500 MWe
- AHWR (300 MWe)
- VVERs/LWRs (1000/1600 MWe)




SCHEMATIC DIAGRAM OF INDIAN PHWR

( COASTAL SITE )

00603/04/202/E-U-01/260

# Type of PHWR Fuel Bundles in Use

**19 ELEMENT BUNDLE  
FOR 220 MWe REACTORS**




**Natural Uranium**


**37 ELEMENT BUNDLE  
FOR 540 MWe REACTORS**



# 19 ELEMENT PHWR FUEL BUNDLE




END VIEW OF FUEL BUNDLE



FUEL ELEMENT


1. ZIRCALOY SHEATH
2. SPACER PAD
3. BEARING PAD
4. UO<sub>2</sub> PELLET
5. END PLUG
6. END PLATE
7. GRAPHITE COATING
8. FILLER GAS
9. PRESSURE TUBE

# PHWR Fuel Element



- No Plenum Space
- Cladding Collapsible Type
- Pellet - Cladding Radial Clearance: Minimum
- Present Maximum Burnup : 15 GWd/TeU
- Higher LHR – Peak value 57 kW/m

# The Fuel element/ Bundles in Reactor to follow such an envelope



# HIGH BURNUP FUEL PLAN

- FUEL DESIGN TO BURNUPS BEYOND 15 000 MWd/TeU
  - 20 000 MWd/TeU TO 30 000 MWd/TeU
- OBJECTIVE : USE OF AVAILABLE AND IMPORTABLE RESOURCES
- MATERIALS - MOX , THORIUM, SEU
- DESIGN AND IRRADIATION STUDIES IN PROGRESS

# Effecting Parameters


- Limiting fission gas pressure within fuel Element
- Fuel swelling
- Axial and Radial Peaking

# Pellet Parameters studied for High Burnup Irradiation

- Increase Void volume within Pellet by
  - Dish depth Increase
  - Density Reduction
    - Grain size
    - Annular Pellets
    - Lower LHR (Linear Heat Rate)

# Comparison of Bundle Power Envelope for SEU and NU Bundles

Figure -4 Bundle Power envelop enriched fuel



# High Burnup fuel element analysis

LHR kW/ M	Variable Parameter	Burnup MWd/T eHE	Centre Tempe ature ( C)	Fission Gas Rel()	Internal gas Pressure (Mpa)
58	Normal Parameters	20,000	2040	15.3	9.8
	Double Dish Pellet	20,000	2040	14.8	5.5
	Grain Size 40 Micro M	20,000	2040	14.7	8.9
	Low Fuel Density	20,000	2080	18.4	7.4
	Central Hole	25,000	1950	14.2	6.4
50	Normal Parameters	25,000	1668	3.7	6.4

# Other Effecting Parameters


- Bundle Residence period increases
    - 3 to 5 years (depending on Bundle location) compared to 2.5 years presently.
- 1) low cycle fatigue behaviour of fuel cladding & end plate
  - 2) corrosion and hydriding behaviour of the fuel cladding and end plate --- **New Zirconium Alloys**
  - 3) fretting damage of fuel bundle
  - 4) power ramps at higher burnups. – **Graphite Coating on Tube ID surface**

# HIGH BURNUP FUEL DESIGN STUDIES - conclusions

- PRESENT FUEL DESIGN ACCEPTABLE UPTO 25000 MWd/TeU
  - With Modification in Pellet dish volume
  - Density
  - Grain size
- BEYOND 25000 MWd/TeU  
19-ELEMENT BUNDLE WITH HOLLOW PELLET  
OR

## 22-Element Fuel Bundle

or Lower LHR  
per Element –  
use 22-  
ELEMENT  
FUEL BUNDLE





# Irradiation Trials of High Burnup Fuels in the PHWRs

- NU Bundles
- ThO<sub>2</sub> Bundles
- MOX Bundles
- SEU Bundles


# Core Map showing Differential Fuelling with two burnup zones



# High burnup NU irradiation

- ◆ Natural uranium 19-element fuel bundles in two channels in KAPS unit are irradiated to burnups of 22000 MWD/TeU.
- ◆ After irradiation bundles both the channels discharged as a normal channel refuelling.
- ◆ Channel powers and bundle powers varied as expected


LHR (kW/m)



Bundle Burnup (MWd/TeU)


Bundle Power variation with Burnup for 7th bundle of Channel O-8

Temperature ( C)



Variation of Channel Outlet Temperature With Reactor Operation of O-8 Channel

# MOX-7 is a 19-element fuel bundle similar to present Nat U 19-element bundle




The MOX constitutes 0.4% PuO<sub>2</sub> mixed in Natural UO<sub>2</sub>.

## **MOX FUEL BUNDLE and CORE DESIGN**

- The core average discharge burnup increases to 9000 MWD/TeHE
- savings in the usage of natural uranium bundles
- REACTOR control, shut down system performance with full core MOX loading checked and safety analysis carried out

# BUNDLE POWER ENVELOPE



# TRIAL IRRADIATION OF 50 MOX-7 BUNDLES

- Reactor Loading Plan For 50 Bundles For Initial Trials
- To Obtain Feed Back On Their Performance Prior To Large Scale Utilization Of MOX-7 Bundles In Phwrs
- Fabrication Drawings And Specifications
- Transport Procedure Developed
- Bundles Fabricated At NFC and BARC

# The loading of 50 MOX-7 bundles in

# KAPS-1



1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20

A

B

C

D

E

1

1

G

H

J

K

I

M

IV

1

U

P

Q

R

S

T


channels contain  
4 MOX-7 bundles  
at 5-8 string  
positions



**These channels  
contain only one  
MOX-7 bundle**



**Initially 4 MOX-  
7 bundles were  
loaded and  
recycled to the  
marked  
channels**



# Data of 50 Discharged Bundles

Residence Period	3 years
Maximum LHR	53.6 kW/m
Maximum Burnup	20000 MWd/TeU
Maximum Power ramp	20 kW/m


## MOX Experience

---

- THE 50 DISCHRGED BUNDLES WET SNIFFED and OBSERVED TO BE NORMAL
- NONE OF THESE BUNDELS FAILED.
- Observed Channel Outlet Temperature of MOX-7 loaded channels matches well with the estimated values
- The worth of S/D systems not affected due to loading of MOX-7 bundles.

LHR  
(KW/m)  
57.5

## BUNDLE POWER VARIATION FOR CH K-03 AND G-09 ( MOX-7 BUNDLE AT STRING 6TH POSITION) FOR KAPS-1




# ThO<sub>2</sub> Bundles Objective

- Experience of Fabrication and irradiation of Thorium
- Flux flattening in the initial core such that the reactor can be operated at rated full power in the initial phase

# The Bundle Loading Plan - 35 Bundles

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	
A																				A	
B																				B	
C																				C	
D																				D	
E																				E	
F																				F	
G																				G	
H																				H	
J																				J	
K																				K	
L																				L	
M																				M	
N																				N	
O																				O	
P																				P	
Q																				Q	
R																				R	
S																				S	
T																				T	
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	


# Bundle Power Envelopes for Natural UO<sub>2</sub> and ThO<sub>2</sub> Fuels



# ThO<sub>2</sub> Bundle Engineering

- DESIGN SIMILAR TO NAT. U BUNDLE DESIGN
    - 1. Flat, low density pellets used for test irradiation in MAPS-1 in 1986
    - 2. Standard dished pellets with high density - used Subsequently
    - 3. Pellet specification evolved at BARC
    - 4. Element axial and radial gaps specified
    - 5. Bundle identification
- Bundles fabricated by NFC


- MAPS-1 4
  - KAPS-1&2 70
  - KGS-1 & 2 70
  - RAPS 3&4 70
  - RAPS-2 18
  - Total 232





# IRRADIATION EXPERIENCE

Bundle power	410 KW
Peak LHR	50.6 KW/m
Bundle Burnup	13000 MWD/Te Th
Residence Period	3 years



## Thorium Bundle Powers and Envelope

- 24 OUT OF 35 BUNDLES SEEN POWER RAMP DURING FUELING


# 19-Element SEU Fuel Bundle

- Full core Loading studies carried out in respect of 0.9% to 1.1 % U-235 isotopic content
- higher burnup and consequently less annual fuel requirement and spent fuel inventory. The core average discharge burnup increases to 14000 MWd/TeU with 1.1% U235
- Refuelling rate comes down to 4 bundles/FPD
- 2/4 bundle fuelling scheme proposed instead of present 8 bundle fuelling scheme

# 19-Element SEU Fuel Bundle

- Fuel design and fabrication issues reviewed.
- 19-element and 22-element fuel bundle use
- Studies on reactor physics characteristics like reactor control, shut down margin, fuel and other systems thermal-hydraulic and material compatibility carried out
- Peak Element Burnup expected 20000 MWd/TeU

# Bundle Power Envelope



# SEU Bundles

- Trial Loading Taken up
- Bundles Fabricated By NFC
- 0.9% SEU 19-element bundles
- Collapsible cladding
- Pellet Design changes - Void volume increased
  - Dish depth – increased
  - Density – Reduced by 1%
- NU pellets kept at the ends of the fuel stack inside the clad to avoid flux peaking
  - Loaded in MAPS-2 Reactor recently

## SEU Bundles' Performance

- Fuelled along with NU and in-core recycled bundles
- The bundle powers of all the SEU bundles are within the bundle power limit.

# Other Bundle Types Test Irradiated in the PHWRs

Bundle Type	Maximum burnup (MWD/TeU)	Maximum LHR (W/cm)
MOX-7	20000 MWD/TeHE	536
Thorium	13000 MWD/Te Th	488
Recycled Uranium	7000 MWD/TeU	550
Natural Uranium	22000 MWD/TeU	550
SEU BUndles	1800 MWD/TeU( so far)	425



*Thank you*

[pnprasad@npcil.co.in](mailto:pnprasad@npcil.co.in)

