

**4th Joint IAEA-GIF Technical Meeting/Workshop on  
Safety of Sodium-Cooled Fast Reactors**

# **Requirements and approaches to BN-1200 safety provision**

**Boris A. Vasilyev<sup>1)</sup>, Sergey F. Shepelev<sup>1)</sup>, Igor A. Bylov<sup>1)</sup>**

**Vladimir M. Poplavskiy<sup>2)</sup>, Iurii M. Ashurko<sup>2)</sup>**

<sup>1)</sup> JSC “OKBM Afrikantov”, Nizhny Novgorod, Russia

<sup>2)</sup> FSUE “SSC RF-IPPE named after A. I. Leypunsky” , Obninsk, Russia

**IAEA HQ, Vienna , Austria, 10-11 June 2014**



# Contents

- BN-1200 design
- Safety requirements
- Inherent safety features
- Passive safety systems
- Design engineering solutions to increase safety
- Approaches to severe accidents analysis
- Conclusion



## BN-1200 design


The BN-1200 next generation sodium-cooled fast reactor is being developed in accordance with Federal Target Programme "A New Generation of Nuclear Power Technologies for 2010-2015 and Prospectively until 2020"

The BN-1200 is next generation reactor plant which should meet all Generation IV systems goals in:

- *Sustainability that meets clean air objectives and provides long-term availability of systems and effective fuel utilisation for worldwide energy production*
- *Safety*
- *Economics*
- *Proliferation resistance and physical protection*

**BN-1200 reactor is developing as sodium-cooled fast reactors design for serial construction**

# Key BN-1200 parameters



Parameter	Value
Thermal power, MW	2800
Electric power, MW	1220
Capacity factor, %	90
Efficiency, %:	
–brutto	43.5
–netto	40.7
Cooling circuits number	3
Primary and secondary circuits coolant	Sodium
3 <sup>rd</sup> circuit coolant	Water/steam
Desing lifetime, years	60
Sodium temperature in the primary circuit at core inlet/outlet, °C	410/550
Sodium temperature in the secondary circuit at SG inlet/outlet, °C	355/527
Live steam pressure, MPa	17.0
Live steam temperature, °C	510
Feedwater temperature, °C	275



# Safety requirements

**BN-1200 design should meet the following safety requirements:**

- *Current regulatory safety requirements for operating nuclear power plants*
- *Core damage frequency should not exceed  $10^{-6}$  1/reactor-year*
- *Large early release frequency should not exceed  $10^{-7}$  1/reactor-year*
- *Elimination of accidents with consequences requiring the need for offsite public evacuation*

**In any technically credible situation, the following requirements must be implemented:**

- *Removal of decay heat generated by the reactor while maintaining its structural integrity*
- *Localization of the majority of radioactive products escaping from the reactor in the event of potential accidents within a special above-reactor premise*
- *The reactor should go subcritical while maintaining acceptable temperature conditions of its components*

**Implementation of all of these requirements should ensure achievement of the objective of precluding offsite public evacuation**



## Inherent safety features (I)

Characteristic	Effect produced
Large heat capacity of integral reactor design (all primary circuit equipment contained inside the reactor vessel)	Low heat-up rate of sodium in the primary circuit (20°C an hour) in case of complete loss of cooling after emergency shutdown
Placement of all systems containing radioactive sodium within the reactor vessel	Exclusion of radioactive sodium release into rooms from external piping
Low corrosive and erosive effect produced by sodium upon structural materials	Exclusion of fuel rod overheating as a consequence of clogging of the fuel assembly open flow area and breach of reactor vessel as a result of corrosion
High boiling temperature of sodium: 883°C at atmospheric pressure	Low, approximately 0.15 MPa, absolute pressure in the reactor gas cavity (sodium boiling temperature 930°C); absence of coolant phase transitions in case of primary circuit depressurization with reliable core cooling



## Inherent safety features (II)

Characteristic	Effect produced
Effective containment of iodine and caesium isotopes by sodium (confirmed by BN-600 operational experience)	Practically full preclusion of any release of the most hazardous gaseous and air-borne fission product isotopes into the environment during normal operation and accidents
Stable negative reactivity coefficient for reactor power ( $dK/dN = -2,6 \cdot 10^{-6} \text{ MW}^{-1}$ ) and core materials temperature ( $dK/dT = -2,3 \cdot 10^{-5} \text{ }^\circ\text{C}^{-1}$ )	Limited reactor power increase in case of unauthorised introduction of positive reactivity, power drop in case of unauthorised reactor heat-up
Introduction of negative reactivity in the event of sodium boiling as a consequence of presence of the top sodium cavity in the fuel assemblies	Reactor power drop in case of core overheating accident to sodium boiling temperature
Design of control and protection rods drive system that precludes simultaneous withdrawal of more than one rod from the core	Exclusion of unauthorised introduction of excessive positive reactivity and dangerous reactor power excursion



## Passive safety systems

**In addition to the inherent safety features BN-1200 design includes number of passive safety devices and passive safety systems**

- Hydraulically suspended absorber rods
- Absorber rods with temperature-triggered action
- Decay heat removal system with air heat exchangers
- Leak-tight above-reactor premise
- Guard vessel
- Core catcher of a heat-resistant metal at the bottom of the reactor vessel




# Decay heat removal system

- **TISEY** testing facility modelling DHRS channel was constructed in OKBM Afrikantov
- DHRS effectiveness was confirmed by experimental researches for natural circulation in transient and steady conditions
- DHRS parameters and operating conditions were ensured by calculations
- Full-scale check valve model manufacturing has been prepared
- Preparation for full-scale check valve model testing in sodium is conducting



## Design engineering solutions to increase safety




To practically exclude radioactive sodium leaks into reactor rooms and accordingly prevent any sodium fires associated with generation of air-borne radioactivity following engineering solutions are adopted in BN-1200 design :


- Placement of all systems containing radioactive sodium within the reactor vessel
- Guard vessel
- Exclusion of the spent fuel assemblies drum – a potential source of accidents involving radioactive sodium

# Design engineering solutions to increase safety: measures to minimize possibilities of non-radioactive sodium leaks (1)

BN-1200 (one loop)




BN-800 (one loop)



**Applying of shell-type steam generators (8 modules) instead of module-type steam generators BN-600 (72 modules) и BN-800 (60 modules) ⇒ substantial decreasing of secondary circuit pipes length**

## Design engineering solutions to increase safety: measures to minimize possibilities of non-radioactive sodium leaks (2)



- Effective prevention and sodium leaks consequences mitigation
- Applying of built-up pipeline shrouds ⇒ sodium leaks localization
- Applying of expansion bellows ⇒ thermal displacement compensation



## Approaches to severe accidents analysis (I)

To assess BN-1200 safety all technically credible even low probability events are taken into consideration

Safety is provided by both technical measures and operational procedures

In addition to regulatory requirements in BN-1200 safety analysis following events are considered:

- *Failure of all active safety systems*
- *Single failures in passive safety systems*

The most severe beyond design basis accidents are analyzed in BN-1200 design as following:

- *Station blackout and reactor shutdown systems failure*
- *Station blackout and emergency heat removal system failure*



## Approaches to severe accidents analysis (II)

In case of realization of such accidents BN-1200 design includes :

- *Two passive reactor shutdown systems employing different action principles:*
  - *Hydraulically suspended absorber rods*
  - *Absorber rods with temperature-triggered action*
  
- *To provide decay heat removal system passive operating additionally to residual heat removal by natural circulation consideration is being given to system operation mode with :*
  - *Air dampers opening without of power sources available*
  - *Air dampers previously slightly opened*
  
- *To assess the level of BN-1200 inherent safety severe accidents with residual risk are analyzed:*
  - *Station blackout and failure of all active and passive safety systems*
  - *Unauthorized withdrawal of all control rods without of initiation of all active and passive reactor shutdown systems*



## Conclusion

**Preliminary evaluations of BN-1200 safety indicate that developed inherent safety features and various passive devices and systems in design allow:**

- *To meet the safety requirements to Generation IV nuclear plants*
- *In particular to eliminate the need for offsite public evacuation in case of any technically credible accidents*



***Thank you for attention!***