

**DND-DNB ALBA/HWY 9 NORTH**

Sample Location (Zone)	Location Designation on Map	Date	Sample Type	Benzene (ug/L)	Other VOC's detected in 524.2? (not including TTHM's) (ug/L)	TTHMs (ug/L)	Total Coliform (MPN)	E.Coli (MPN)	Free Cl2 (mg/L)	Total Cl2 (mg/L)	pH	Color	Odor (TON)	Turbidity (NTU)	Nitrate (mg/L as N)	
Rebecca and Elsie Mae (Nina Zone)	Location 1	9/1/2020	Flush sample	Non Detect	Non Detect	3.5	<1.0	<1.0	1.05	1.05	7.2	ND	ND	0.45	0.62	
		9/2/2020	Flush sample	Non Detect	Non Detect	5	1.0	<1.0	0.89	0.92	7.4	ND	ND	0.6	0.7	
		9/3/2020	Flush sample	Non Detect	Non Detect	5.4	<1.0	<1.0	0.94	1.04	7.2	ND	ND	0.55	0.69	
		9/4/2020	Flush sample	Non Detect	Non Detect	3.9			0.96	1.06						
		9/12/2020	Flush sample	Non Detect	Non Detect	4.4										
600 Debbie (Highland Zone)	Location 2	9/1/2020	Flush sample	Non Detect	Non Detect	3.3	<1.0	<1.0	1.06	1.17	7.3	3	ND	0.35	0.6	
		9/2/2020	Flush sample	Non Detect	Non Detect	3.4	<1.0	<1.0	0.97	1.11	7.2	ND	ND	0.5	0.53	
		9/3/2020	Flush sample	Non Detect	Non Detect	5	<1.0	<1.0	0.94	1.13	7.1	ND	ND	0.5	0.66	
		9/4/2020	Flush sample	Non Detect	Non Detect	4.8			0.94	1.03						
		9/12/2020	Flush sample	Non Detect	Non Detect	4										
Hwy 9 and Alameda (Big Steel Zone)	Location 3	8/31/2020	Flush sample	Non Detect	Non Detect	2.6			0.76							
		9/1/2020	Flush sample	Non Detect	Non Detect	3.4	<1.0	<1.0	0.97	0.96	7.2	ND	ND	0.3	0.58	
		9/2/2020	Flush sample	Non Detect	Non Detect	4.8	<1.0	<1.0	0.76	0.85	7.2	ND	ND	0.4	0.5	
		9/3/2020	Flush sample	Non Detect	Non Detect	4.9	<1.0	<1.0	0.48	0.56	7.1	4	ND	0.9	0.61	
		9/12/2020	Flush sample	Non Detect	Non Detect	3										
12788 Hwy 9 (Big Steel Zone)	Location 4	8/26/2020	Flush sample	Non Detect	Non Detect				0.96							
		8/31/2020	Flush sample	Non Detect	Non Detect	2.3			1.11							
		9/1/2020	Flush sample	Non Detect	Non Detect	2.4	<1.0	<1.0	1.14	1.28	7.1	ND	ND	0.25	0.57	
		9/2/2020	Flush sample	Non Detect	Non Detect	2.3	<1.0	<1.0	0.99	1.11	7.2	ND	ND	0.5	0.56	
		9/3/2020	Flush sample	Non Detect	Non Detect	3.6	<1.0	<1.0	1.07	1.12	7	ND	ND	0.55	0.65	
		9/4/2020	Flush sample	Non Detect	Non Detect	Non Detect			1.04	1.1						
		9/12/2020	Flush sample	Non Detect	Non Detect	2.7										
		9/16/2020	Flush sample	Non Detect	Non Detect	3.7										
		9/18/2020	Flush sample	Non Detect	Non Detect	2.4										
Boulder Creek Fire Dept (Big Steel Zone)	Location 5	8/30/2020	Flush sample	Non Detect	Non Detect	2.5			0.77							
		8/31/2020	Flush sample	Non Detect	Non Detect	2.5			0.93							
		9/1/2020	Flush sample	Non Detect	Non Detect	3.2										
		9/2/2020	Flush sample	Non Detect	Non Detect	3	<1.0	<1.0	0.68	0.79	7.2	ND	ND	0.6	0.54	
		9/3/2020	Flush sample	Non Detect	Non Detect	3.5	<1.0	<1.0	0.76	0.86	7	ND	ND	0.55	0.62	
		9/4/2020	Flush sample	Non Detect	Non Detect	3.6	<1.0	<1.0	0.84	0.88	7.1	ND	ND	1.4	0.6	
		9/6/2020	Flush sample	Non Detect	Non Detect	3.2										
		9/7/2020	Flush sample	Non Detect	Non Detect	3.2										
		9/12/2020	Flush sample	Non Detect	Non Detect	3.3										
Hazel and Davidson Hydrant (Big Steel Zone)	Location 37	9/14/2020	Flush Sample	Non Detect	Non Detect	3.8										
15177 Bear Creek Rd (Reader Zone)	Location 6	8/31/2020	Flush sample	Non Detect	Non Detect	6.1			0.84							
		9/1/2020	Flush sample	Non Detect	Non Detect	4.6	<1.0	<1.0	1	1.06	7.1	ND	ND	0.4	0.7	
		9/2/2020	Flush sample	Non Detect	Non Detect	4.2	<1.0	<1.0	0.71	0.84	7.1	ND	ND	0.25	0.59	
		9/3/2020	Flush sample	Non Detect	Non Detect	3.7	<1.0	<1.0	0.92	1.06	7	ND	ND	0.35	0.6	
		9/4/2020	Flush sample	Non Detect	Non Detect	3.6			0.97							
		9/12/2020	Flush sample	Non Detect	Non Detect	4										
		9/18/2020	Flush sample	Non Detect	Non Detect	4.4										
15030 Hwy 9 (Reader Zone)	Location 7	8/31/2020	Flush sample	Non Detect	Non Detect	3.1			1.0							
		9/2/2020	Flush sample	Non Detect	Non Detect	2.7	<1.0	<1.0	0.99	1	7.1	ND	ND	0.5	0.56	
		9/3/2020	Flush sample	Non Detect	Non Detect	3.6	<1.0	<1.0	0.71	0.77	7	ND	ND	0.6	0.59	
		9/4/2020	Flush sample	Non Detect	Non Detect	3.5										
		9/9/2020	Flush sample	Non Detect	Non Detect	4.5										
		9/10/2020	Flush sample	Non Detect	Non Detect	3.9										
		9/11/2020	Flush sample	Non Detect	Non Detect	5.2										
		9/12/2020	Flush sample	Non Detect	Non Detect	5.2										
		9/13/2020	Flush sample	Non Detect	Non Detect	3										
		9/16/2020	Flush sample	Non Detect	Non Detect	4										
Riverdale Blvd and Hillside Hydrant (Reader Zone)	Location 38	9/17/2020	Flush Sample	Non Detect	Non Detect	4.7										
Brookdale St and Lilac Hydrant (Reader Zone)	Location 39	9/14/2020	Flush Sample	Non Detect	Non Detect	4.7										
		9/16/2020	Flush Sample	Non Detect	Non Detect	3.4										
		9/17/2020	Flush Sample	Non Detect	Non Detect	4.9										
Brookdale St and Eden Hydrant (Reader Zone)	Location 40	9/17/2020	Flush Sample	Non Detect	Non Detect	5.2										
Spring Creek Rd Hydrant at 575 Spring Creek (Reader)	Location 41	9/14/2020	Flush Sample	Non Detect	Non Detect	5.7										
		9/16/2020	Flush Sample	Non Detect	Non Detect	6.6										
Band and Sunset Rd Hydrant (Reader Zone)	Location 42	9/14/2020	Flush Sample	Non Detect	Non Detect	2.9										
		9/16/2020	Flush Sample	Non Detect	Non Detect	4.1										
		9/17/2020	Flush Sample	Non Detect	Non Detect	6										
Band and Pleasant Hydrant (Reader Zone)	Location 43	9/16/2020	Flush Sample	Non Detect	Non Detect	4.2										
		9/17/2020	Flush Sample	Non Detect	Non Detect	5.9										









**DND-DNB FELTON**

Sample Location (Zone)	Location Designation on Map	Date	Sample Type	Benzene (ug/L)	Other VOCs detected in 524.2? (not including TTHM's) (ug/L)	TTHMs (ug/L)	Total Coliform (MPN)	E.Coli (MPN)	Free Cl2 (mg/L)	Total Cl2 (mg/L)	pH	Color	Odor (TON)	Turbidity (NTU)	Nitrate (mg/L as N)
1150 Featherston	Location 22	9/2/2020	Flush sample	Non Detect	Non Detect	Non Detect	<1.0	<1.0	0.71	0.71	7.7	ND	ND	1.5	ND
		9/3/2020	Flush sample	Non Detect	Non Detect	Non Detect	<1.0	<1.0	0.63	0.54	7.5	ND	ND	0.95	ND
		9/4/2020	Flush sample	Non Detect	Non Detect	Non Detect	<1.0	<1.0	0.64	0.66	7.7	ND	ND	0.9	ND
		9/10/2020	Flush sample	Non Detect	Non Detect	Non Detect	<1.0	<1.0	0.89	0.9	7.5	ND	ND	0.25	ND
		9/11/2020	Flush sample	Non Detect	Non Detect	Non Detect	<1.0	<1.0	0.73	0.78	7.5	ND	ND	0.3	ND
871 Jenny Wy	Location 23	9/2/2020	Flush sample	Non Detect	Non Detect	Non Detect	<1.0	<1.0	0.37	0.37	7.6	5	ND	7.4	ND
		9/3/2020	Flush sample	Non Detect	Non Detect	Non Detect	<1.0	<1.0	0.43	0.43	7.5	4	ND	2	ND
		9/4/2020	Flush sample	Non Detect	Non Detect	Non Detect	<1.0	<1.0	0.56	0.56	7.6	ND	ND	1.5	ND
		9/10/2020	Flush sample	Non Detect	Non Detect	Non Detect	<1.0	<1.0	0.83	0.86	7.6	7	ND	7.4	ND
		9/11/2020	Flush sample	Non Detect	Non Detect	1	<1.0	<1.0	0.53	0.5	7.4	ND	ND	0.3	ND
Bennett Chlorination Tank	Location 24	8/27/2020	Flush sample	Non Detect	Non Detect	Non Detect			0.96						
Kirby Clearwell Effluent	Location 25	8/27/2020	Flush sample	Non Detect	Non Detect	14			0.99						